


# **PROBLEM SUMMARY**




# 5 Utilities/030 Boiler House/B Blower/Fan/702A #9 FD Fan East 30B702A WEST FAN BEARING

**Blower** 

PETRO CANADA TURBOFLO 68 (1 LTR)

## **COMPONENT CONDITION SUMMARY**



## **RECOMMENDATION**

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS										
Sample Status			SEVERE	SEVERE						
Particles >4µm	ASTM D7647	>2500	<b>42885</b>	<b>224943</b>						
Particles >6µm	ASTM D7647	>640	<b>7724</b>	<b>88905</b>						
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>23/20/13</b>	<b>25/24/15</b>						

**Customer Id: PETMIS** Sample No.: WC Lab Number: 02629929 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Filter			?	We recommend you service the filters on this component.			
Resample			?	Resample in 30-45 days to monitor this situation.			
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.			
Check Seals			?	Check seals and/or filters for points of contaminant entry.			

# HISTORICAL DIAGNOSIS

# 25 Oct 2016 Diag: Bill Quesnel



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Oil Cleanliness is severe. Particles >14µm are abnormally high. Particles >21µm are notably high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.






# **OIL ANALYSIS REPORT**

# 5 Utilities/030 Boiler House/B Blower/Fan/702A #9 FD Fan East 30B702A WEST FAN BEARING

Blower

PETRO CANADA TURBOFLO 68 (1 LTR)



## **DIAGNOSIS**

#### Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

All component wear rates are normal.

# Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

			0ct2016	Apr2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		wc	WC22118386	
Sample Date		Client Info		04 Apr 2024	25 Oct 2016	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				SEVERE	SEVERE	
CONTAMINATION	I	method	limit/base	current	history1	history2
Water		WC Method		NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	0	59	
Chromium	ppm	ASTM D5185(m)	>20	0	<1	
Nickel	ppm	ASTM D5185(m)	>20	0	<1	
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		0	0	
Aluminum	ppm	ASTM D5185(m)		0	3	
Lead	ppm	ASTM D5185(m)	>20	0	0	
Copper	ppm	ASTM D5185(m)	>20	<1	<1	
Tin	ppm	ASTM D5185(m)	>20	0	0	
Antimony	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	0	0	
Barium	ppm	ASTM D5185(m)	0	0	0	
Molybdenum	ppm	ASTM D5185(m)	0	0	0	
Manganese	ppm	ASTM D5185(m)	0	0	<1	
Magnesium	ppm	ASTM D5185(m)	0	0	0	
Calcium	ppm	ASTM D5185(m)	0	0	2	
Phosphorus	ppm	ASTM D5185(m)	120	0	106	
Zinc	ppm	ASTM D5185(m)	0.0	<1	<1	
Sulfur	ppm	ASTM D5185(m)	50	582	27	
Lithium	ppm	ASTM D5185(m)		<1	<1	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0	3	
Sodium	ppm	ASTM D5185(m)	. 20	<1	2	
Potassium	ppm	ASTM D5185(m)	>20	0	0	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	<b>42885</b>	<u>224943</u>	
Particles >6µm		ASTM D7647	>640	<b>▲</b> 7724	▲ 88905	
Particles >14µm		ASTM D7647	>80	47	▲ 317	
Particles >21µm		ASTM D7647	>20	4	33	
Particles >38µm		ASTM D7647	>4	1	0	
Particles >71μm		ASTM D7647	>3	1	0	


ISO 4406 (c) >18/16/13 **A 23/20/13** 

Oil Cleanliness

**25/24/15** 



# **OIL ANALYSIS REPORT**





CALA ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Sample No.

Lab Number Unique Number : 5763061

: WC : 02629929

Diagnosed Test Package : IND 2 ( Additional Tests: TAN Man )

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Received

**Tested** 

: 18 Apr 2024

: 18 Apr 2024

: 18 Apr 2024 - Wes Davis

Petro Canada Lubricants Inc.

385 Southdown Road Mississauga, ON CA L5J 2Y3 Contact: Kyle Blezard kyle.blezard@HFSinclair.com T: (905)403-6768

F: (905)822-6025