



OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
[4517]
 Machine Id
04-019-CE
 Component
Oil
 Fluid
PETRO CANADA SUPREME C3X SYNTHETIC 5W30 (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Fluid Condition

Pour Point = -39°C.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PP0000937	---	---
Sample Date	Client Info		17 Apr 2024	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			NORMAL	---	---

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method		NEG	---	---



VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	---	---
Precipitate	scalar	Visual*	NONE	---	---
Silt	scalar	Visual*	NONE	---	---
Debris	scalar	Visual*	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	---	---
Appearance	scalar	Visual*	NORML	---	---
Odor	scalar	Visual*	NORML	---	---

FLUID PROPERTIES

	method	limit/base	current	history1	history2
Pour Point	°C	ASTM D97*	-48	-39	---

SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



OIL ANALYSIS REPORT

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP0000937 **Received** : 18 Apr 2024
Lab Number : 02630024 **Tested** : 19 Apr 2024
Unique Number : 5763156 **Diagnosed** : 19 Apr 2024 - Kevin Marson
Test Package : TEST (Additional Tests: PourPt, Visual)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Oleo Energies
 5800 Thorold Stone Road
 Niagara Falls, ON
 CA L2J 1A2
 Contact: Mark Michalkoff
 mmichalkoff@oleoenergies.com
 T: (905)358-5133
 F: