




# OIL ANALYSIS REPORT

Sample Rating Trend



CONTAMINANT



Machine Id

## Unit #1, West CW Pump Upper (S/N 7147)

Component

### Upper Bearing

Fluid

### PETRO CANADA HYDREX AW 32 (25 LTR)

#### DIAGNOSIS

##### ▲ Recommendation

This is a baseline read-out on the submitted sample. NOTE: The bottle submitted was empty (no oil was present) therefore we could not perform any tests.

#### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC</b>	WC0805167	WC0805171
Sample Date	Client Info		<b>09 Apr 2024</b>	23 Nov 2023	02 May 2023
Machine Age	mths	Client Info	<b>0</b>	0	0
Oil Age	mths	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	ABNORMAL

#### CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>2	<b>NEG</b>	NEG	NEG

#### VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	<b>NONE</b>	NONE	VLITE
Yellow Metal	scalar	Visual*	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	<b>NONE</b>	VLITE	VLITE
Sand/Dirt	scalar	Visual*	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	<b>NORML</b> ▲ <b>NOOIL</b>	NORML	NORML
Odor	scalar	Visual*	<b>NORML</b>	NORML	NORML

#### SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color					
Bottom					



# OIL ANALYSIS REPORT

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC  
**Lab Number** : 02630038  
**Unique Number** : 5763170  
**Test Package** : TEST

**Received** : 18 Apr 2024  
**Tested** : 18 Apr 2024  
**Diagnosed** : 19 Apr 2024 - Kevin Marson

**NEWFOUNDLAND & LABRADOR HYDRO**  
 HOLYROOD THERMAL GEN. STN., PO BOX 29, DUFFS RD  
 CONCEPTION BAY, NL  
 CA A0A 2R0  
 Contact: Rory Tweedie  
 rorytweedie@nlh.nl.ca  
 T: (709)229-2764  
 F: (709)229-7894

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.