




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

NOVA 1637

Component

Natural Gas Engine

Fluid

VALVOLINE PREMIUM BLUE 9200 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0917657	WC0891065	WC0830080
Sample Date	Client Info			13 Apr 2024	22 Jan 2024	19 Oct 2023
Machine Age	kms	Client Info		466944	450680	431724
Oil Age	kms	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>50	15	23	19
Chromium	ppm	ASTM D5185(m)	>4	<1	1	<1
Nickel	ppm	ASTM D5185(m)	>2	<1	1	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>3	0	0	<1
Aluminum	ppm	ASTM D5185(m)	>9	4	2	2
Lead	ppm	ASTM D5185(m)	>30	3	5	1
Copper	ppm	ASTM D5185(m)	>35	1	2	5
Tin	ppm	ASTM D5185(m)	>4	<1	2	<1
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		10	9	23
Barium	ppm	ASTM D5185(m)		0	<1	6
Molybdenum	ppm	ASTM D5185(m)		54	58	49
Manganese	ppm	ASTM D5185(m)		<1	2	7
Magnesium	ppm	ASTM D5185(m)		819	836	779
Calcium	ppm	ASTM D5185(m)		1257	1367	1185
Phosphorus	ppm	ASTM D5185(m)		640	683	695
Zinc	ppm	ASTM D5185(m)		852	915	791
Sulfur	ppm	ASTM D5185(m)		1849	2100	1861
Lithium	ppm	ASTM D5185(m)		<1	<1	<1



CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>+100	10	13	31
Sodium	ppm	ASTM D5185(m)		5	8	16
Potassium	ppm	ASTM D5185(m)	>20	<1	1	<1

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	12.7	13.0	8.4
Sulfation	Abs/.1mm	ASTM D7415*	>30	24.4	25.1	19.5

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	20.8	21.5	16.6











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	14.8	14.3	14.0

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0917657
Lab Number : 02630106
Unique Number : 5763238
Test Package : MOB 1
Received : 19 Apr 2024
Tested : 19 Apr 2024
Diagnosed : 19 Apr 2024 - Wes Davis

CITY OF HAMILTON
 2200 UPPER JAMES., MOUNTAIN TRANSIT STOREROOM
 MOUNT HOPE, ON
 CA L0R LW0
 Contact: Jeff Parr
 jeff.parr@hamilton.ca
 T: (905)546-2424
 F: (905)679-4502

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.