




# PROBLEM SUMMARY

## Sample Rating Trend




ISO



Machine Id  
**30TP701B**  
 Component  
**Inboard Bearing**  
 Fluid  
**R&O OIL ISO 68 (--- GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) R&O OIL ISO 68. Please confirm.  
 NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>SEVERE</b>	---	---
Particles >4µm	ASTM D7647	>10000	▲ <b>114792</b>	---	---
Particles >6µm	ASTM D7647	>2500	▲ <b>26635</b>	---	---
Particles >14µm	ASTM D7647	>160	▲ <b>341</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ <b>24/22/16</b>	---	---

**Customer Id:** PETMIS  
**Sample No.:** WC22119793  
**Lab Number:** 02630183  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Apr 22 2024	?	We recommend you service the filters on this component.
Resample	MISSED	Apr 22 2024	?	Resample in 30-45 days to monitor this situation.
Alert	MISSED	Apr 22 2024	?	Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment.
Information Required	MISSED	Apr 22 2024	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	MISSED	Apr 22 2024	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	MISSED	Apr 22 2024	?	Check seals and/or filters for points of contaminant entry.

## HISTORICAL DIAGNOSIS



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**30TP701B**  
 Component  
**Inboard Bearing**  
 Fluid  
**R&O OIL ISO 68 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) R&O OIL ISO 68. Please confirm.

NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC22119793</b>	---	---
Sample Date	Client Info		<b>16 Apr 2024</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>N/A</b>	---	---
Sample Status			<b>SEVERE</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	<b>3</b>	---
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	---
Nickel	ppm	ASTM D5185(m)	>20	<b>0</b>	---
Titanium	ppm	ASTM D5185(m)		<b>0</b>	---
Silver	ppm	ASTM D5185(m)		<b>0</b>	---
Aluminum	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	---
Lead	ppm	ASTM D5185(m)	>20	<b>0</b>	---
Copper	ppm	ASTM D5185(m)	>20	<b>1</b>	---
Tin	ppm	ASTM D5185(m)	>20	<b>3</b>	---
Antimony	ppm	ASTM D5185(m)		<b>0</b>	---
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	---
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	---
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	5	<b>0</b>	---
Barium	ppm	ASTM D5185(m)	5	<b>0</b>	---
Molybdenum	ppm	ASTM D5185(m)	5	<b>0</b>	---
Manganese	ppm	ASTM D5185(m)		<b>0</b>	---
Magnesium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	---
Calcium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	---
Phosphorus	ppm	ASTM D5185(m)	100	<b>5</b>	---
Zinc	ppm	ASTM D5185(m)	25	<b>3</b>	---
Sulfur	ppm	ASTM D5185(m)	1500	<b>651</b>	---
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	---

## CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	<b>0</b>	---
Sodium	ppm	ASTM D5185(m)		<b>0</b>	---
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	---
Water	%	ASTM D6304*	>2	<b>0.006</b>	---
ppm Water	ppm	ASTM D6304*		<b>61</b>	---

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>▲ 114792</b>	---	---
Particles >6µm	ASTM D7647	>2500	<b>▲ 26635</b>	---	---
Particles >14µm	ASTM D7647	>160	<b>▲ 341</b>	---	---
Particles >21µm	ASTM D7647	>40	<b>● 62</b>	---	---
Particles >38µm	ASTM D7647	>10	<b>4</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>1</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/14	<b>▲ 24/22/16</b>	---	---



# OIL ANALYSIS REPORT



FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.08	<b>0.03</b>	---	---




VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	---	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Debris	scalar	Visual*	NONE	<b>VLITE</b>	---	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Appearance	scalar	Visual*	NORML	<b>NORML</b>	---	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	---	---
Emulsified Water	scalar	Visual*	>2	<b>.2%</b>	---	---
Free Water	scalar	Visual*		<b>NEG</b>	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	68	<b>67.7</b>	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC22119793 **Received** : 19 Apr 2024  
**Lab Number** : **02630183** **Tested** : 22 Apr 2024  
**Unique Number** : 5763315 **Diagnosed** : 22 Apr 2024 - Wes Davis  
**Test Package** : IND 2 ( Additional Tests: KF )

**Petro Canada Lubricants Inc.**  
 385 Southdown Road  
 Mississauga, ON  
 CA L5J 2Y3  
 Contact: Kyle Blezard  
 kyle.blezard@HFSinclair.com  
 T: (905)403-6768  
 F: (905)822-6025

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.