




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
Lime Kilns Route #2 [102295]
 Machine Id
KVS 12.5 102295 K1 P1 SE Bearing
 Component
Bearing
 Fluid
MOBIL MOBILGEAR SHC 1500 (40 LTR)

DIAGNOSIS

Recommendation
 Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is no indication of any contamination in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0890803	WC0877633	WC0868748
Sample Date	Client Info		09 Apr 2024	12 Dec 2023	17 Nov 2023
Machine Age	yrs	Client Info	0	0	0
Oil Age	yrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	SEVERE	SEVERE

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>2	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	40
Iron	ppm	ASTM D5185(m) >75	16	77	160
Chromium	ppm	ASTM D5185(m) >20	0	<1	<1
Nickel	ppm	ASTM D5185(m) >20	<1	3	9
Titanium	ppm	ASTM D5185(m)	5	<1	2
Silver	ppm	ASTM D5185(m)	0	<1	1
Aluminum	ppm	ASTM D5185(m) >20	<1	<1	1
Lead	ppm	ASTM D5185(m) >150	93	393	1251
Copper	ppm	ASTM D5185(m) >250	241	948	2779
Tin	ppm	ASTM D5185(m) >20	17	80	201
Antimony	ppm	ASTM D5185(m)	2	14	36
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	24	19	22
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	<1
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	2	2	6
Calcium	ppm	ASTM D5185(m)	14	45	177
Phosphorus	ppm	ASTM D5185(m)	166	84	207
Zinc	ppm	ASTM D5185(m)	5	8	23
Sulfur	ppm	ASTM D5185(m)	3449	1676	2447
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	10	17	22
Sodium	ppm	ASTM D5185(m)	2	<1	2
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.90	1.44	2.65




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	1500	1535	1648

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0890803 **Received** : 19 Apr 2024
Lab Number : 02630252 **Tested** : 23 Apr 2024
Unique Number : 5763384 **Diagnosed** : 23 Apr 2024 - Wes Davis
Test Package : IND 2 (Additional Tests: TAN Man)

CARMEUSE LIME
 374681 OXFORD COUNTY ROAD 6., P.O. BOX 190
 INGERSOLL, ON
 CA N5C 3K5
 Contact: Jeff Geddes
 jeff.geddes@carmeusena.com
 T: (519)423-6283
 F: (519)423-6568

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.