


# **OIL ANALYSIS REPORT**



Swift Current LTC System #1 [GTT224-440 1-10VPWFA] YORK 11531G53981497(1,1)

Componer Chiller

YORK TYPE L (--- GAL)





### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

The water content is negligible. There is no indication of any contamination in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

.)				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GTT0003250		
Sample Date		Client Info		30 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>8	0		
Chromium	ppm	ASTM D5185(m)	>2	0		
Nickel	ppm	ASTM D5185(m)		0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>3	0		
Lead	ppm	ASTM D5185(m)	>2	<1		
Copper	ppm	ASTM D5185(m)	>8	<1		
Tin	ppm	ASTM D5185(m)	>4	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1		
Barium	ppm	ASTM D5185(m)	0	0		
Molybdenum	ppm	ASTM D5185(m)	0	0		
Manganese	ppm	ASTM D5185(m)	0	0		
Magnesium	ppm	ASTM D5185(m)	0	<1		
Calcium	ppm	ASTM D5185(m)	0	0		
Phosphorus	ppm	ASTM D5185(m)	0	0		
Zinc	ppm	ASTM D5185(m)	0	<1		
Sulfur	ppm	ASTM D5185(m)	10	61		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	11		
Sodium	ppm	ASTM D5185(m)		0		
Potassium	ppm	ASTM D5185(m)	>20	0		
ppm Water	ppm	ASTM D6304*	>300	127		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Asid Number (ANI)	ma 1/011/-	ACTM D074*	0.00	0.01		

Acid Number (AN)

mg KOH/g ASTM D974\* 0.02

0.01



# **OIL ANALYSIS REPORT**

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	120	103		
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image
GRAPHS						



Sample No. : GTT0003250 Received : 10 Jun 2024 **Lab Number** : 02640964 Tested : 14 Jun 2024

Unique Number : 5798503

Test Package : IND 2 ( Additional Tests: KV40 )

To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

Diagnosed : 14 Jun 2024 - Bill Quesnel

Contact: Service Manager T:

Accounts Payable A-33C, P.O. Box 2012

Johnson Controls -Sask

Contact/Location: Service Manager - GTT0000163

F:

Milwaukee, WI

US 532012012