


# **OIL ANALYSIS REPORT**

Area [200096574]

# **SULLAIR LS10095 GRN-CMP-529**

Component Compressor

SULLAIR SULLUBE 32/46 (--- GAL)





### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the


### **Fluid Condition**

The condition of the oil is acceptable for the time in service.

SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0940537	WC0605831	
Sample Date		Client Info		25 May 2024	03 Jul 2022	
Machine Age	hrs	Client Info		0	15728	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Not Changd	Not Changd	
Sample Status				NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>50	<1	2	
Chromium	ppm	ASTM D5185(m)	>5	0	0	
Nickel	ppm	ASTM D5185(m)		0	0	
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		0	0	
Aluminum	ppm	ASTM D5185(m)	>15	<1	<1	
Lead	ppm	ASTM D5185(m)	>65	0	<1	
Copper	ppm	ASTM D5185(m)	>65	<1	<1	
Tin	ppm	ASTM D5185(m)	>10	0	0	
Antimony	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1	2	
Barium	ppm	ASTM D5185(m)	745	893	889	
Molybdenum	ppm	ASTM D5185(m)		0	0	
Manganese	ppm	ASTM D5185(m)		0	0	
Magnesium	ppm	ASTM D5185(m)		2	2	
Calcium	ppm	ASTM D5185(m)	1	2	4	
Phosphorus	ppm	ASTM D5185(m)	3	<1	1	
Zinc	ppm	ASTM D5185(m)		5	5	
Sulfur	ppm	ASTM D5185(m)		292	297	
Lithium	ppm	ASTM D5185(m)		<1	<1	
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>35	0	<1	
Sodium	ppm	ASTM D5185(m)		35	41	
Potassium	ppm	ASTM D5185(m)	>20	5	4	



## **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	
Precipitate	scalar	Visual*	NONE	NONE	NONE	
Silt	scalar	Visual*	NONE	NONE	NONE	
Debris	scalar	Visual*	NONE	NONE	NONE	
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	
Appearance	scalar	Visual*	NORML	NORML	NORML	
Odor	scalar	Visual*	NORML	NORML	NORML	
<b>Emulsified Water</b>	scalar	Visual*	>0.1	NEG	NEG	
Free Water	scalar	Visual*		NEG	NEG	
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		44.5	41.1	

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					no image
Bottom					no image
GRAPHS					
Iron (ppm)		150 T	Lead (ppm)		
- Severe			Severe		
) + Abnormal	•••••	E 100 -	Abnormal		
2			- 52		
Jul3/22		May25/24	Jul3/22		
Aluminum (ppm)		_	Chromium (pp	om)	,
Severe		15 T	Severe		
Abnormal		E 10+	Abnormal		
		0			
Jul3/22		May25/24	Jul3/22 -		
يار					
Copper (ppm)		100	Silicon (ppm)		
Severe		100	Severe		



CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: WC0940537

Lab Number : 02641155 Unique Number : 5798694

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received

: 11 Jun 2024 **Tested** : 11 Jun 2024 Diagnosed : 11 Jun 2024 - Wes Davis

Additives

1350 Government Rd. W, MACASSA COMPLEX Kirkland Lake, ON CA P2N 3J1

Agnico Eagle Canada

Test Package : MOB 1 To discuss this sample report, contact Customer Service at 1-800-268-2131.

Viscosity @ 40°C

Contact: Mitch Lamontagne AEM\_KL\_macassaoilsampleresults@agnicoeagle.com T: (705)567-5208

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

F: (705)567-5221 Contact/Location: Mitch Lamontagne - KIR370KIR