




PROBLEM SUMMARY

Area
(C-GQNJ)
 Machine Id
[C-GQNJ] BEECHCRAFT KING AIR 200 PCE-PJ1306
 Component
Left Jet Turbine
 Fluid
EASTMAN TURBO OIL 2380 (12 QTS)


Sample Rating Trend



DIRT



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status		SEVERE	NORMAL	NORMAL
Silicon	ppm ASTM D5185(m) >8	▲ 29	<1	0

Customer Id: FASWIN
 Sample No.: WC0932415
 Lab Number: 02641395
 Test Package: AVI 3



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

NORMAL



01 Apr 2024 Diag: Kevin Marson

Resample at the next service interval to monitor. All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



NORMAL



08 Jan 2024 Diag: Kevin Marson

Resample at the next service interval to monitor. All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



NORMAL



30 Oct 2023 Diag: Bill Quesnel


Resample at the next service interval to monitor. All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Area
(C-GQNJ)
 Machine Id
[C-GQNJ] BEECHCRAFT KING AIR 200 PCE-PJ1306
 Component
Left Jet Turbine
 Fluid
EASTMAN TURBO OIL 2380 (12 QTS)

DIAGNOSIS

Recommendation
 Check seals and/or filters for points of contaminant entry. We recommend an early resample to monitor this condition.

Wear
 All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.

Contaminants
 Elemental level of silicon (Si) above normal indicating ingress of seal material, dirt and/or grease. The water content is negligible.

Oil Condition
 The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0932415	WC0911748	WC0887240
Sample Date	Client Info		04 Jun 2024	01 Apr 2024	08 Jan 2024
TSN	hrs	Client Info	5712	5524	5330
TSO	hrs	Client Info	5712	5524	5330
Oil Age	hrs	Client Info	982	795	600
Oil Changed		Client Info	N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>8	0	0
Chromium	ppm	ASTM D5185(m)	>2	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	<1
Titanium	ppm	ASTM D5185(m)	>2	0	0
Silver	ppm	ASTM D5185(m)	>2	0	0
Aluminum	ppm	ASTM D5185(m)	>2	0	<1
Lead	ppm	ASTM D5185(m)	>3	0	0
Copper	ppm	ASTM D5185(m)	>3	0	0
Tin	ppm	ASTM D5185(m)	>2	0	0
Antimony	ppm	ASTM D5185(m)		0	0
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	0
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)		0	0
Magnesium	ppm	ASTM D5185(m)	0	<1	<1
Calcium	ppm	ASTM D5185(m)	0	0	0
Phosphorus	ppm	ASTM D5185(m)	2500	2561	2660
Zinc	ppm	ASTM D5185(m)	0	1	<1
Sulfur	ppm	ASTM D5185(m)	0	2	0
Lithium	ppm	ASTM D5185(m)		<1	<1






CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>8	▲ 29	<1
Sodium	ppm	ASTM D5185(m)		0	0
Potassium	ppm	ASTM D5185(m)	>20	0	<1
Water	%	ASTM D6304*	>0.1	0.052	0.016
ppm Water	ppm	ASTM D6304*	>1000	523	164

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.43	0.24	0.31

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	24.2	24.3	24.3	24.3
Visc @ 100°C	cSt	ASTM D7279(m)	4.97	5.0	5.0	5
Viscosity Index (VI)	Scale	ASTM D2270*	134	135	135	135

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0932415 **Received** : 12 Jun 2024
Lab Number : **02641395** **Tested** : 17 Jun 2024
Unique Number : 5798934 **Diagnosed** : 17 Jun 2024 - Kevin Marson
Test Package : AVI 3

FAST AIR LTD
 80 HANGAR LINE ROAD
 WINNIPEG, MB
 CA R3J 3Y7
 Contact: Denis Bourgouin
 denis.bourgouin@flyfastair.com
 T: (204)772-7622
 F: (204)783-2483

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.


FERROGRAPHY REPORT

Area
(C-GQNJ)
 Machine Id
[C-GQNJ] BEECHCRAFT KING AIR 200 PCE-PJ1306
 Component
Left Jet Turbine
 Fluid
EASTMAN TURBO OIL 2380 (12 QTS)

Magn: 200x Illum: BC



Magn: 50x Illum: RW



Magn: 100x Illum: RW




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		1.3	3.8	1.0
Small Particles		DR-Ferr*		0.4	3.4	0.8
Total Particles		DR-Ferr*	>---	1.7	7.2	1.8
Large Particles Percentage	%	DR-Ferr*		52.9	5.6	11.1
Severity Index		DR-Ferr*		1	2	0

FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		2	1	1
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*		1	1	1
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*				
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*				
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		1	1	1
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*		1	1	1

WEAR

All component wear rates are normal.
 The ferrography results are normal indicating no abnormal wear in the system.



This page left intentionally blank