

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area Vicinity Energy - 888095 FK420-RM

Unknown Component Fluid CHEVRON DELO 710 LE (--- GAL)

DIAGNOSIS

Recommendation

We certify this oil to be dry. Oil cleanliness compares favourably to virgin oil reference ISO 22/19/15 (FK421).


Fluid Condition

Sodium ppm levels are notably high.


			1			
SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Machine ID		Client Info		Engine Oil Pan		
Department		Client Info		Sales		
Sample From		Client Info		Machine		
Production Stage		Client Info		Lab Reclaim		
Sent to WC		Client Info		06/10/2024		
Sample Number		Client Info		E30002364		
Sample Date		Client Info		10 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)		4		
Chromium	ppm	ASTM D5185(m)		5		
Nickel	ppm	ASTM D5185(m)		0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)		1		
Lead	ppm	ASTM D5185(m)		2		
Copper	ppm	ASTM D5185(m)		2		
Tin	ppm	ASTM D5185(m)		0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		46		
Barium	ppm	ASTM D5185(m)		<1		
Molybdenum	ppm	ASTM D5185(m)		42		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		19		
Calcium	ppm	ASTM D5185(m)		2890		
Phosphorus	ppm	ASTM D5185(m)		17		
Zinc	ppm	ASTM D5185(m)	10	21		
Sulfur	ppm	ASTM D5185(m)		1801		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		2		
Sodium	ppm	ASTM D5185(m)		577		
Potassium	ppm	ASTM D5185(m)	>20	10		
Water	%	ASTM D6304*		0.016		
ppm Water	ppm	ASTM D6304*		161		




OIL ANALYSIS REPORT









FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	22602		
Particles >6µm		ASTM D7647	>640	282		
Particles >14µm		ASTM D7647	>160	27		
Particles >21µm		ASTM D7647	>40	5		
Particles >38µm		ASTM D7647	>10	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/16/14	22/15/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		0.06		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
Emulsified Water	scalar	Visual*		NEG		
Free Water	scalar	Visual*		NEG		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	136.4	130		
Visc @ 100°C	cSt	ASTM D7279(m)	15.5	14.2		
Viscosity Index (VI)	Scale	ASTM D2270*	117	107		
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color					no image	no image
Bottom				\bigcirc	no image	no image



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA : E30002364 Received : 12 Jun 2024 Sample No. Lab Number : 02641409 Tested : 13 Jun 2024 ISO 17025:2017 Accredited Laboratory Unique Number : 5798948 Diagnosed : 14 Jun 2024 - Tatiana Sorkina Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI) To discuss this sample report, contact Customer Service at 1-905-372-2251. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Environmental 360 Solutions Ltd. 640 Victoria Street Cobourg, ON CA K9A 5H5 Contact: Tatiana Sorkina tsorkina@e360s.ca T: (800)263-3939 F: (905)373-4950

Report Id: CHECOB [WCAMIS] 02641409 (Generated: 06/14/2024 09:36:35) Rev: 1

10/24

Contact/Location: Tatiana Sorkina - CHECOB

Page 2 of 2