

FUEL REPORT



Machine Id

PENSKE GT UU5647

Component Diesel Fuel

Fluid No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

Contaminants

There is no bacteria or fungus (yeast and/or mold) present in the sample. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.

Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0799416		
Sample Date		Client Info		10 Jun 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.830		
Fuel Color	text	Visual Screen*	Yllow	Yllow		
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.1		
Pensky-Martens Flash Point	°C	ASTM D7215*	52	49.7		
SULFUR CONTEN	١T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	9		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	157		
5% Distillation Point	°C	ASTM D2887*		179		
10% Distill Point	°C	ASTM D2887*	201	190		
15% Distillation Point	°C	ASTM D2887*		198		
20% Distill Point	°C	ASTM D2887*	216	206		
30% Distill Point	°C	ASTM D2887*	230	222		
40% Distill Point	°C	ASTM D2887*	243	236		
50% Distill Point	°C	ASTM D2887*	255	251		
60% Distill Point	°C	ASTM D2887*	267	266		
70% Distill Point	°C	ASTM D2887*	280	281		
80% Distill Point	°C	ASTM D2887*	295	298		
85% Distillation Point	°C	ASTM D2887*		308		
90% Distill Point	°C	ASTM D2887*	310	319		
95% Distillation Point	°C	ASTM D2887*	0.4.1	336		
Final Boiling Point	°C	ASTM D2887*	341	365		
IGNITION QUALIT	٦Y	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	38		
Cetane Index		ASTM D4737*	<40.0	49		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	<0.1	<1		
Potassium	ppm	ASTM D5185(m)	<0.1	0		
Water	%	ASTM D6304*	< 0.05	0.018		
ppm Water	ppm	ASTM D6304*	<500	184		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	1413		
Particles >6µm		ASTM D7647	>640	373		
Particles >14µm		ASTM D7647	>80	27		
Particles >21µm		ASTM D7647	>20	5		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647		0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	18/16/12	 ocation: Matt Tu	

Contact/Location: Matt Tuckey - FREOTT Page 1 of 2



FUEL REPORT

Particle Count 20 T T ²⁶	MICROBIAL		method	limit/base	e current	history1	history2
-24	Bacteria	CFU/ml	ASTM D6469*	>=100000	0		
20 Severe 222 8	Yeast	CFU/ml	ASTM D6469*	>=100000	0		
20 Severe - 22 'S 80 Abnormal - 20 (5) (199 9) 80 - 16 0) 80 - 16 0)	Mold	Colonies	ASTM D6469*	MODER	NONE		
20- +14 =.	HEAVY METALS		method	limit/base	e current	history1	history2
12	Aluminum	ppm	ASTM D5185(m)	<0.1	0		
	Nickel	ppm	ASTM D5185(m)	<0.1	0		
0	Lead	ppm	ASTM D5185(m)	<0.1	0		
⁴ μ 6μ 14μ 21μ 38μ 71μ	Vanadium	ppm	ASTM D5185(m)	<0.1	0		
Water (KF)	Iron	ppm	ASTM D5185(m)	<0.1	0		
00 - Gevere	Calcium	ppm	ASTM D5185(m)	<0.1	0		
00 -	Magnesium	ppm	ASTM D5185(m)	<0.1	0		
00-	Phosphorus	ppm	ASTM D5185(m)	<0.1	0		
Abnormal	Zinc	ppm	ASTM D5185(m)	<0.1	0		
	SAMPLE IMAGE	S	method	limit/base	e current	history1	history2
2 					1		
Jun 10/24	Color					no image	no image
Viscosity @ 40°C					and the second	0	5
6 [
Abnormal	Bottom					no image	no image
4 Abnormal							
Base							
2 - Abnomal	GRAPHS						
1+ 1	Fuel Distillation Cu 380°C T	urve			Pensky-Marter	ns Flash Point (°C)
Particle Trend ^{3k} ^{4μm} ^{4μm} ^{4μm} ^{4μm} ^{4μm} ^{4μm}	340°C -				45 40 35 40 40 40 40 40 40 40 40 40 40 40 40 40		
2k	300°C -		1		⊰ GCD Spectrun	n	
	280°C -		1	15,0		(90%)	
Gas Chromatography (GCD)	220°C 220°C 200°C 180°C 160°C 120°C 120°C 120°C 120°C 120°C 120°C			11., 10, 10, 10, 10, 10, 10, 10, 10, 10, 11, 11	000 - 000 - 000 -	e de la construcción de la const	
Laboratory Sample No. Lab Number	: WearCheck - C8-117 : WC0799416	5 Appleby Recei Teste	Line, Burlin ved : 12	gton, ON L 2 Jun 2024 9 Jun 2024	7L 5H9	FRANCIS TR	
Accredited Unique Number	: 5799088 : FUEL (Additional Tes t, contact Customer Serv	Diagn sts: Bacte rice at 1-8	o sed : 19 ria, CC Flasl <i>00-268-213</i> 1	Jun 2024 - K n, PrtCount /.	:)	matt.tuc	CA K1G 3 CA K1G 3 ct: Matt Tuck key@fctci.co (613)744-09

Report Id: FREOTT [WCAMIS] 02641549 (Generated: 06/19/2024 12:08:53) Rev: 1

Contact/Location: Matt Tuckey - FREOTT Page 2 of 2