




OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area

[25938]

Machine Id

CARRIER 365POW CHILLER (S/N 3811Q21049)

Component

Compressor

Fluid

COMP OIL (POE) ISO 68 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

Viscosity of sample indicates oil is within ISO 46 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PP0001121	PP0001419	---
Sample Date	Client Info		12 Jun 2024	28 May 2024	---
Machine Age	hrs	Client Info	13739	13537	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	---
Iron	ppm	ASTM D5185(m) >50	<1	<1	---
Chromium	ppm	ASTM D5185(m) >10	0	0	---
Nickel	ppm	ASTM D5185(m)	0	0	---
Titanium	ppm	ASTM D5185(m)	0	0	---
Silver	ppm	ASTM D5185(m)	0	0	---
Aluminum	ppm	ASTM D5185(m) >25	0	0	---
Lead	ppm	ASTM D5185(m) >25	0	<1	---
Copper	ppm	ASTM D5185(m) >50	<1	<1	---
Tin	ppm	ASTM D5185(m) >15	0	0	---
Antimony	ppm	ASTM D5185(m)	0	0	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 5	<1	1	---
Barium	ppm	ASTM D5185(m) 5	0	0	---
Molybdenum	ppm	ASTM D5185(m) 5	0	0	---
Manganese	ppm	ASTM D5185(m)	0	0	---
Magnesium	ppm	ASTM D5185(m) 5	<1	<1	---
Calcium	ppm	ASTM D5185(m) 5	0	0	---
Phosphorus	ppm	ASTM D5185(m) 400	1795	1770	---
Zinc	ppm	ASTM D5185(m) 5	3	11	---
Sulfur	ppm	ASTM D5185(m) 100	24	178	---
Lithium	ppm	ASTM D5185(m)	<1	<1	---

CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	22	20	---
Sodium	ppm	ASTM D5185(m)	<1	<1	---
Potassium	ppm	ASTM D5185(m) >20	<1	0	---
Water	%	ASTM D6304* >0.1	0.016	0.008	---
ppm Water	ppm	ASTM D6304* >1000	163	89	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.40	0.11	0.11	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	FREON	---
Emulsified Water	scalar	Visual*	>0.1	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68 ▲ 47.4	▲ 46.5	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP0001121 **Received** : 13 Jun 2024
Lab Number : 02641754 **Tested** : 14 Jun 2024
Unique Number : 5799293 **Diagnosed** : 14 Jun 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: KF, TAN Man)

Complete Chiller Solutions
 8-4444 Eastgate Parkway
 Mississauga, ON
 CA L4W 4T6
 Contact: Neil Patten
 neil@complete-cs.ca
 T: (905)629-8585
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.