

OIL ANALYSIS REPORT

Sample Rating Trend





Hop Trois-Riviere REF-101 [GTT224-437 853796] CARRIER 4502Q02129(12B) Chiller

COMP OIL (POE) ISO 220 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GTT0003244		
Sample Date		Client Info		25 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>8	2		
Chromium	ppm	ASTM D5185(m)	>2	0		
Nickel	ppm	ASTM D5185(m)		<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>3	0		
Lead	ppm	ASTM D5185(m)	>2	0		
Copper	ppm	ASTM D5185(m)	>8	2		
Tin	ppm	ASTM D5185(m)	>4	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES	1-1-	method	limit/base	current	history1	history2
Boron		ASTM D5185(m)	5	<1		
Barium	ppm	ASTM D5185(m)	5	0		
	ppm	()	5	-		
Molybdenum	ppm	ASTM D5185(m)	C	0		
Manganese	ppm	ASTM D5185(m)	-	∪ <1		
Magnesium	ppm	ASTM D5185(m)	5			
Calcium	ppm	ASTM D5185(m)		0		
Phosphorus	ppm	ASTM D5185(m)	400	8		
Zinc	ppm	ASTM D5185(m)		3		
Sulfur	ppm	ASTM D5185(m)	100	32		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	23		
Sodium	ppm	ASTM D5185(m)		<1		
Potassium	ppm	ASTM D5185(m)	>20	0		
ppm Water	ppm	ASTM D6304*	>100	171		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.40	0.01		



OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history1	history2		
White Metal	scalar	Visual*	NONE	NONE				
Yellow Metal	scalar	Visual*	NONE	NONE				
Precipitate	scalar	Visual*	NONE	NONE				
Silt	scalar	Visual*	NONE	NONE				
Debris	scalar	Visual*	NONE	NONE				
Sand/Dirt	scalar	Visual*	NONE	NONE				
Appearance	scalar	Visual*	NORML	NORML				
Odor	scalar	Visual*	NORML	NORML				
FLUID PROPERT	IES	method	limit/base	current	history1	history2		
Visc @ 40°C	cSt	ASTM D7279(m)	220	124				
SAMPLE IMAGES		method	limit/base	current	history1	history2		
Color					no image	no image		
Bottom					no image	no image		
GRAPHS								



Lab Number : 02642233 Tested : 24 Jun 2024 Quebec, QC Unique Number : 5799772 Diagnosed : 24 Jun 2024 - Bill Quesnel CA G1N 2E7 Test Package : IND 2 (Additional Tests: KV40) Contact: Service Manager To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26. invoices@ainsworth.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

: 14 Jun 2024

Received

Report Id: GTT0000601 [WCAMIS] 02642233 (Generated: 06/24/2024 12:22:44) Rev: 1

Sample No. : GTT0003244

Contact/Location: Service Manager - GTT0000601 Page 2 of 2

1375 Fran-Carrell, bureau 16 Quebec

Ainsworth Inc.

T:

F: