


COOLANT REPORT

WAJAX [6100287098] MTU 5362003457 GEN B

Coolant

DETROIT DIESEL POWER COOL (--- LTR)



DIAGNOSIS

Recommendation

We recommend drain system, and refill with 50/50 antifreeze water mixture. We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer's specifications. We recommend an early resample to monitor this condition.

Corrosion

The iron level is high indicating rust in the system which clogs the cooling system.

There is no indication of any contamination in the coolant.

Coolant Condition

The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0018428	WA0012723	WA0015312
Sample Date		Client Info		11 Jun 2024	07 Nov 2022	23 Jun 2021
Machine Age	hrs	Client Info		0	604	500
Oil Age	hrs	Client Info		0	0	25
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	NORMAL
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR		UNK		
Specific Gravity		ASTM D1298*		1.068	1.067	1.067
pН	Scale 0-14	ASTM D1287*	9.5	8.80	8.87	9.17
Nitrites	ppm	Alcan Test Kit*	500	880	1600	1680
Reserve Alkalinity	Scale 0-20	ASTM D1121*		5.5	3.9	3.3
Percentage Glycol	%	ASTM D3321*	50	50.8	50.0	50.0
Freezing Point	°C	ASTM D3321*	-40	-37	-35	-37
Carboxylate						
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	150	45	57	44
Phosphorus	ppm	ASTM D5185(m)	0	26	25	28
Boron	ppm	ASTM D5185(m)	300	295	337	295
Molybdenum	ppm	ASTM D5185(m)		2	3	1
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	<u> </u>	<u>^</u> 20	9
Aluminum	ppm	ASTM D5185(m)	>10	0	<1	<1
Copper	ppm	ASTM D5185(m)	>10	0	2	<1
Lead	ppm	ASTM D5185(m)	>10	0	<1	1
Tin	ppm	ASTM D5185(m)	>10	0	0	<1
Silver	ppm	ASTM D5185(m)	>10	<1	1	0
Zinc	ppm	ASTM D5185(m)		<1	2	<1
CARRIER SALTS	;	method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		2191	1915	1694
Potassium	ppm	ASTM D5185(m)		30	23	21
		ام مالم مما	limit/base	current	history1	history2
SCALE POTENT	AL	method	IIIIIIIIIIIIIII	Current	HISTOLYT	Thotol y Z
SCALE POTENT	ppm	ASTM D5185(m)	>100	< 1	5	2



COOLANT REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

Lab Number : 02642424 Unique Number : 5799963

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WA0018428

Received : 17 Jun 2024 **Tested** : 21 Jun 2024 Diagnosed

: 21 Jun 2024 - Kevin Marson

Test Package : COOL (Additional Tests: GlycolType, PQ) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems

70 Raddall Avenue Dartmouth, NS **CA B3B 1T7**

Contact: Danelle Hoffman dhoffman@wajax.com T: (902)468-6200

F: (902)468-3325