


## **FUEL REPORT**

[6100302919] LOUTEC

Component

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)





# DIAGNOSIS

#### Recommendation

This is a baseline read-out on the submitted sample.

#### Contaminants

The diesel fuel contains >80% gasoline.


### ▲ Fuel Condition

Pensky-Martens Flash Point is severely low. 20% Distill Point results are abnormally low. 50% Distill Point results are abnormally low. 90% Distill Point and cetane index results are abnormally low.

i) ( GAL)						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0021408		
Sample Date		Client Info		13 Jun 2024		
Machine Age	hrs	Client Info		0		
Sample Status				SEVERE		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	<b>△</b> 0.774		
Fuel Color	text	Visual Screen*	Yllow	Yllow		
Pensky-Martens Flash Point	°C	ASTM D7215*	52	<b>-26.7</b>		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	53		
5% Distillation Point	°C	ASTM D2887*		66		
10% Distill Point	°C	ASTM D2887*	201	81		
15% Distillation Point	°C	ASTM D2887*		93		
20% Distill Point	°C	ASTM D2887*	216	<b>105</b>		
30% Distill Point	°C	ASTM D2887*	230	129		
40% Distill Point	°C	ASTM D2887*	243	153		
50% Distill Point	°C	ASTM D2887*	255	<u> </u>		
60% Distill Point	°C	ASTM D2887*	267	201		
70% Distill Point	°C	ASTM D2887*	280	224		
80% Distill Point	°C	ASTM D2887*	295	252		
85% Distillation Point	°C	ASTM D2887*		269		
90% Distill Point	°C	ASTM D2887*	310	286		
95% Distillation Point	°C	ASTM D2887*		312		
Final Boiling Point	°C	ASTM D2887*	341	352		
IGNITION QUALIT	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	51		
Cetane Index		ASTM D4737*	<40.0	48		
CONTAMINANTS		method	limit/base		history1	history2
Water	%	ASTM D6304*	<0.05	△ 0.055		
ppm Water		ASTM D6304*	<500	▲ 560		
ppiii watei	ppm	A31W D0304	<300	560		
MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	ASTM D6469*	>=100000	0		
Yeast	CFU/ml	ASTM D6469*	>=100000	0		
Mold	Colonies	ASTM D6469*	MODER	NONE		
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image



### **FUEL REPORT**





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: WA0021408 Lab Number : 02642434 Unique Number : 5799973

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : 17 Jun 2024 Received

**Tested** : 21 Jun 2024 Diagnosed

: 21 Jun 2024 - Kevin Marson Test Package : TEST ( Additional Tests: API, Bacteria, CC Flash, Cetane, Fuel, GCD, KF, Spat Contact: Steve Racine

**Wajax Limited** 2997 AV. WATT Quebec, QC **CA G1X 3W1** 

sracine@wajax.com

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

T: F: (418)651-4448

Validity of results and interpretation are based on the sample and information as supplied. Report Id: DETSTE [WCAMIS] 02642434 (Generated: 06/21/2024 12:33:13) Rev: 1

Contact/Location: Steve Racine - DETSTE