




PROBLEM SUMMARY


Machine Id
HCP G1 TUBR
 Component
Turbine
 Fluid
MOBIL DTE OIL HVY MEDIUM (27 LTR)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



▲ Particle Trend



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status		SEVERE	ABNORMAL	SEVERE
Copper	ppm ASTM D5185(m) >5	▲ 34	▲ 21	▲ 35
Particles >6µm	ASTM D7647 >640	▲ 43262	▲ 3588	▲ 3843
Particles >14µm	ASTM D7647 >80	▲ 3326	50	▲ 231
Particles >21µm	ASTM D7647 >20	▲ 819	10	▲ 61
Particles >38µm	ASTM D7647 >4	▲ 66	1	2
Oil Cleanliness	ISO 4406 (c) >--/16/13	▲ 24/23/19	▲ 22/19/13	▲ 21/19/15

Customer Id: NEWSTJ
 Sample No.: WC0706095
 Lab Number: 02642924
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.

HISTORICAL DIAGNOSIS

WEAR



04 May 2023 Diag: Kevin Marson

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Copper ppm levels are abnormal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



WEAR



27 May 2022 Diag: Kevin Marson

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Copper ppm levels are severe. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >6µm and oil cleanliness are abnormally high. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



WEAR



21 Oct 2021 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Copper ppm levels are severe. Lead ppm levels are abnormal. A sharp increase in the copper level is noted. An increase in the lead level is noted. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Particles >38µm are abnormally high. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
HCP G1 TUBR

Component
Turbine

Fluid
MOBIL DTE OIL HVY MEDIUM (27 LTR)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

Wear

Copper ppm levels are severe.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0706095	WC0455583	WC0445386
Sample Date	Client Info		16 Apr 2024	04 May 2023	27 May 2022
Machine Age	hrs	Client Info	0	80	80
Oil Age	hrs	Client Info	0	80	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >15	2	2	1
Chromium	ppm	ASTM D5185(m) >4	0	0	0
Nickel	ppm	ASTM D5185(m) >2	<1	0	0
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	<1	<1
Aluminum	ppm	ASTM D5185(m) >10	<1	<1	0
Lead	ppm	ASTM D5185(m)	13	18	18
Copper	ppm	ASTM D5185(m) >5	▲ 34	▲ 21	▲ 35
Tin	ppm	ASTM D5185(m) >5	0	0	0
Antimony	ppm	ASTM D5185(m)	0	<1	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	0
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	<1	0	0
Calcium	ppm	ASTM D5185(m)	1	0	0
Phosphorus	ppm	ASTM D5185(m)	118	138	134
Zinc	ppm	ASTM D5185(m)	29	42	40
Sulfur	ppm	ASTM D5185(m)	1327	1623	649
Lithium	ppm	ASTM D5185(m)	<1	<1	<1


CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	1	1	<1
Sodium	ppm	ASTM D5185(m)	2	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1
Water	%	ASTM D6304* >0.03	0.001	0.026	0.001
ppm Water	ppm	ASTM D6304* >300	5	260.9	14.1


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		113857	22347	17409
Particles >6µm	ASTM D7647	>640	▲ 43262	▲ 3588	▲ 3843
Particles >14µm	ASTM D7647	>80	▲ 3326	50	▲ 231
Particles >21µm	ASTM D7647	>20	▲ 819	10	▲ 61
Particles >38µm	ASTM D7647	>4	▲ 66	1	2
Particles >71µm	ASTM D7647	>3	5	0	0
Oil Cleanliness	ISO 4406 (c)	>--/16/13	▲ 24/23/19	▲ 22/19/13	▲ 21/19/15


▲ Particle Trend




Water (KF)




▲ Non-ferrous Metals



Acid Number



Water (KF)




FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.03	0.05	0.08
VISUAL					
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.03	NEG	NEG
Free Water	scalar	Visual*	NEG	NEG	NEG

FLUID PROPERTIES


	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	63.7	65.0	67.3

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




▲ Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0706095
Lab Number : 02642924
Unique Number : 5800463
Test Package : IND 2 (Additional Tests: TAN Auto)
Received : 19 Jun 2024
Tested : 20 Jun 2024
Diagnosed : 20 Jun 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com

T:
 F: (709)737-2926