




PROBLEM SUMMARY

Machine Id
SCV G2 THBR

Component
Thrust Bearing


Fluid
MOBIL DTE OIL HVY MEDIUM (24 LTR)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>10000	▲ 210130	▲ 151252	▲ 164444	
Particles >6µm	ASTM D7647	>2500	▲ 54996	▲ 42196	▲ 123398	
Particles >14µm	ASTM D7647	>160	▲ 659	▲ 742	▲ 13170	
Particles >21µm	ASTM D7647	>40	▲ 171	▲ 201	▲ 1035	
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 25/23/17	▲ 24/23/17	▲ 25/24/21	
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	NONE
Appearance	scalar	Visual*	NORML	▲ WGOIL	▲ WGOIL	▲ LAYRD
Free Water	scalar	Visual*		▲ 1%	▲ 1%	▲ >10%
PrtFilter						

Customer Id: NEWSTJ
Sample No.: WC0706236
Lab Number: 02642961
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

ISO



05 Feb 2024 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. Copper ppm levels are abnormal. Bearing wear is indicated. There is a high amount of particulates (2 to 100 microns in size) present in the oil. Free water present. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



WEAR



20 Jun 2023 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the oil from the component if this has not already been done. Resample in 30-45 days to monitor this situation. Copper ppm levels are severe. Lead ppm levels are noted. Bearing wear is indicated. There is a high amount of particulates (2 to 100 microns in size) present in the oil. There is a moderate concentration of water present in the oil. Excessive free water present. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



ISO



08 Nov 2022 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm and oil cleanliness are severely high. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
SCV G2 THBR

Component
Thrust Bearing

Fluid
MOBIL DTE OIL HVY MEDIUM (24 LTR)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

Wear

Light concentration of visible metal present.


Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. Free water present.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

Particle Filter (Magn: 100 x)



SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0706236	WC0706200	WC0445324
Sample Date	Client Info		18 Jun 2024	05 Feb 2024	20 Jun 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>85	15	17	27
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	1
Aluminum	ppm	ASTM D5185(m)	>40	<1	<1	0
Lead	ppm	ASTM D5185(m)	>60	8	21	25
Copper	ppm	ASTM D5185(m)	>7	5	10	19
Tin	ppm	ASTM D5185(m)	>40	16	15	21
Antimony	ppm	ASTM D5185(m)		1	1	2
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<1	0	<1
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		<1	0	0
Calcium	ppm	ASTM D5185(m)		<1	1	<1
Phosphorus	ppm	ASTM D5185(m)		116	154	125
Zinc	ppm	ASTM D5185(m)		80	60	56
Sulfur	ppm	ASTM D5185(m)		1097	1582	1474
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>20	<1	2	3
Sodium	ppm	ASTM D5185(m)		0	0	0
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Water	%	ASTM D6304*	>2	0.040	0.008	---
ppm Water	ppm	ASTM D6304*		404	83	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	210130	151252	164444
Particles >6µm	ASTM D7647	>2500	54996	42196	123398
Particles >14µm	ASTM D7647	>160	659	742	13170
Particles >21µm	ASTM D7647	>40	171	201	1035
Particles >38µm	ASTM D7647	>10	14	16	5
Particles >71µm	ASTM D7647	>3	1	1	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	25/23/17	24/23/17	25/24/21



OIL ANALYSIS REPORT




FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.14	0.12	0.10

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	▲ WGOIL	▲ WGOIL
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	.5%	.2%
Free Water	scalar	Visual*		▲ 1%	▲ >10%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	69.3	61.6	63.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0706236
Lab Number : 02642961
Unique Number : 5800500
Test Package : IND 2 (Additional Tests: BottomAnalysis, FilterPatch, KF, PrtCount, PrtFilter, TAN MaC)

NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T: (709)737-2926
 Submitted By: Shane Reid