




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
BRUCE B/5/33120
 Machine Id
5-33120-P3-PM Lower Brg
 Component
Lower Bearing
 Fluid
MOBIL DTE 732 (30 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

The Direct-Reading Ferrographic data (DL, DS, %large) is normal. All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC	WC0900687	WC
Sample Date	Client Info	10 Jun 2024	11 Mar 2024	18 Dec 2023
Machine Age	hrs Client Info	0	0	0
Oil Age	hrs Client Info	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m) >1	0	0	0
Chromium	ppm ASTM D5185(m) >1	0	0	0
Nickel	ppm ASTM D5185(m) >1	<1	<1	0
Titanium	ppm ASTM D5185(m) >5	0	0	0
Silver	ppm ASTM D5185(m)	0	0	0
Aluminum	ppm ASTM D5185(m) >1	<1	<1	<1
Lead	ppm ASTM D5185(m) >3	0	0	<1
Copper	ppm ASTM D5185(m) >1	<1	0	0
Tin	ppm ASTM D5185(m) >1	0	0	0
Antimony	ppm ASTM D5185(m)	0	0	0
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	0	0	0

DR-FERROGRAPHY

method	limit/base	current	history1	history2
Large Particles	DR-Ferr*	2.5	0.4	5.4
Small Particles	DR-Ferr*	2.9	0.2	1.3
Total Particles	DR-Ferr* >---	5.4	0.6	6.7
Large Particles Percentage	% DR-Ferr*	0	33.3	61.2
Severity Index	DR-Ferr*	1	0	22

ADDITIVES






method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)	0	0	0
Barium	ppm ASTM D5185(m)	0	0	0
Molybdenum	ppm ASTM D5185(m)	0	0	0
Manganese	ppm ASTM D5185(m)	0	0	0
Magnesium	ppm ASTM D5185(m)	<1	0	<1
Calcium	ppm ASTM D5185(m)	<1	0	0
Phosphorus	ppm ASTM D5185(m)	0	0	0
Zinc	ppm ASTM D5185(m)	<1	<1	<1
Sulfur	ppm ASTM D5185(m)	49	35	34
Lithium	ppm ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >5	0	0	0
Sodium	ppm ASTM D5185(m) >5	0	0	0
Potassium	ppm ASTM D5185(m) >20	<1	<1	0
Water	% ASTM D6304* >0.005	0.001	0.002	0.002
ppm Water	ppm ASTM D6304* >50	13	22	22



OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	419	374	157
Particles >6µm	ASTM D7647	>1300	128	119	55
Particles >14µm	ASTM D7647	>320	10	11	3
Particles >21µm	ASTM D7647	>80	3	2	0
Particles >38µm	ASTM D7647	>20	0	0	0
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/15	16/14/10	16/14/11	14/13/9

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974*	0.10	0.05	0.04	0.06

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar Visual*	NONE	NONE	NONE	NONE
Silt	scalar Visual*	NONE	NONE	NONE	NONE
Debris	scalar Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar Visual*	NONE	NONE	NONE	NONE
Appearance	scalar Visual*	NORML	NORML	NORML	NORML
Odor	scalar Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual*	>0.005	NEG	NEG	NEG
Free Water	scalar Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	30.0	31.8	31.9	29.1

SAMPLE IMAGES



Color

Bottom



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC
Lab Number : 02642977
Unique Number : 5800516
Test Package : IND 2 (Additional Tests: Bottom, DR-Ferr, RPVOT, TAN Man)

Bruce Power - Bruce A PdM
 P.O.Box 1540, 177 Tie Road, RM-222 U2 Column 2N11 615'
 Tiverton, ON
 CA N0G 2T0
 Contact: Pierre Adouki
 pierre.adouki@brucepower.com
 T: (519)361-2673
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.