




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

Port Steering Gear (S/N T2P01011)

Component

Port Steering

Fluid

PETRO CANADA HYDREX MV 32 (114 LTR)

DIAGNOSIS

Recommendation

The fluid change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the fluid.

Fluid Condition

The AN level is acceptable for this fluid. The fluid is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0829982	WC0829977	WC0754148
Sample Date	Client Info	05 Jun 2024	09 Aug 2023	21 Jun 2023
Machine Age	hrs	Client Info	19920	18400
Oil Age	hrs	Client Info	920	18400
Oil Changed	Client Info	Changed	Not Changd	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method	>0.2	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185(m)	>50	<1	3	3
Chromium	ppm	ASTM D5185(m)	>15	0	0	0
Nickel	ppm	ASTM D5185(m)	>5	<1	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	<1	0
Aluminum	ppm	ASTM D5185(m)	>5	<1	0	0
Lead	ppm	ASTM D5185(m)	>10	0	<1	1
Copper	ppm	ASTM D5185(m)	>50	3	12	14
Tin	ppm	ASTM D5185(m)	>5	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	<1	0

ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	<1	4	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	1	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	1	<1	1
Calcium	ppm	ASTM D5185(m)	50	45	31	37
Phosphorus	ppm	ASTM D5185(m)	330	318	390	362
Zinc	ppm	ASTM D5185(m)	430	403	398	399
Sulfur	ppm	ASTM D5185(m)	760	790	1043	947
Lithium	ppm	ASTM D5185(m)		<1	<1	<1


CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	>15	0	<1	<1
Sodium	ppm	ASTM D5185(m)		<1	<1	1
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1


FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	▲ 12549	▲ 11492	● 4969
Particles >6µm	ASTM D7647	>640	▲ 3523	▲ 3157	▲ 1578
Particles >14µm	ASTM D7647	>80	▲ 255	▲ 267	▲ 171
Particles >21µm	ASTM D7647	>20	▲ 61	▲ 62	▲ 46
Particles >38µm	ASTM D7647	>4	6	2	2
Particles >71µm	ASTM D7647	>3	2	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 21/19/15	▲ 21/19/15	▲ 19/18/15


Particle Trend




Particle Trend



Acid Number



Viscosity @ 40°C




FLUID DEGRADATION

method	limit/base	current	history1	history2		
Acid Number (AN) mg KOH/g	ASTM D974*	0.60	0.50	0.40	0.31	
VISUAL						
method	limit/base	current	history1	history2		
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	VLITE	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES


method	limit/base	current	history1	history2		
Visc @ 40°C	cSt	ASTM D7279(m)	31.9	31.7	32.8	31.8

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0829982
Lab Number : 02643279
Unique Number : 5800818
Test Package : MAR 2 (Additional Tests: PrtCount, TAN Man)
Received : 20 Jun 2024
Tested : 21 Jun 2024
Diagnosed : 21 Jun 2024 - Wes Davis

CANADIAN COAST GUARD
 CCGS Vladkov, P.O. Box 5667, 280 Southside Rd.
 St. John's, NL
 CA A1C 5X1
 Contact: Geoff Stewart
 geoffrey.stewart@dfo-mpo.gc.ca
 T: (709)772-4216
 F: (709)772-3652

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.