




PROBLEM SUMMARY

Sample Rating Trend




WEAR




Machine Id
SKV BALL MILL DISCHARGE
 Component
Reservoir Bearing
 Fluid
MOBIL MOBILGEAR SHC 220 (129 LTR)

COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



Aluminum (ppm)



RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	NORMAL	NORMAL
Lead	ppm	ASTM D5185(m) >20	▲ 218	28	49
Antimony	ppm	ASTM D5185(m)	▲ 31	2	6

Customer Id: REIBLI
 Sample No.: WC0951870
 Lab Number: 02643512
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

NORMAL



08 Oct 2022 Diag: Kevin Marson

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



29 Aug 2016 Diag: Kevin Marson

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



WEAR



22 Oct 2014 Diag: Kevin Marson

The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition. Lead ppm levels are abnormal. Antimony ppm levels are noted. Bearing wear is indicated. Calcium and/or magnesium levels higher than normal indicating possible lime contamination, advise investigate. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
SKV BALL MILL DISCHARGE

Component
Reservoir Bearing

Fluid
MOBIL MOBILGEAR SHC 220 (129 LTR)

DIAGNOSIS

▲ Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

▲ Wear

Lead ppm levels are severe. Antimony ppm levels are abnormal. Tin ppm levels are noted. Bearing wear is indicated.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0951870	WC0686028	WC939809
Sample Date	Client Info		19 Jun 2024	08 Oct 2022	29 Aug 2016
Machine Age	hrs	Client Info	0	0	97000
Oil Age	hrs	Client Info	0	0	6000
Oil Changed	Client Info		Not Chngd	N/A	Not Chngd
Sample Status			SEVERE	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>2	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	15
Iron	ppm	ASTM D5185(m) >20	8	4	6
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >20	<1	0	<1
Titanium	ppm	ASTM D5185(m)	<1	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >20	4	0	<1
Lead	ppm	ASTM D5185(m) >20	▲ 218	28	49
Copper	ppm	ASTM D5185(m) >20	1	<1	<1
Tin	ppm	ASTM D5185(m) >20	● 10	<1	2
Antimony	ppm	ASTM D5185(m)	▲ 31	2	6
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	<1
Barium	ppm	ASTM D5185(m)	<1	0	<1
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	2	<1	<1
Calcium	ppm	ASTM D5185(m)	32	21	16
Phosphorus	ppm	ASTM D5185(m)	368	453	397
Zinc	ppm	ASTM D5185(m)	2	4	<1
Sulfur	ppm	ASTM D5185(m)	1686	1782	1871
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	15	22	17
Sodium	ppm	ASTM D5185(m)	0	<1	0
Potassium	ppm	ASTM D5185(m) >20	1	<1	<1

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.63	0.75	0.55



OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	LTMOD
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	220	218	224

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0951870 **Received** : 21 Jun 2024
Lab Number : **02643512** **Tested** : 24 Jun 2024
Unique Number : 5801051 **Diagnosed** : 24 Jun 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

CARMEUSE LIME CANADA LTD.
 BOX 1690., HWY 17 EAST
 BLIND RIVER, ON
 CA P0R 1B0
 Contact: Rejean Baillargeon
 rejean.baillargeon@carmeusena.com
 T: (705)849-2201
 F: (705)849-2355

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.