

## FUEL REPORT

Sample Rating Trend

### NORMAL

## Area **ROGERS CALL CENTRE [154384] CUMMINS**

Diesel Fuel Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

#### DIAGNOSIS

#### Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

#### Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.

#### **Fuel Condition**


All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		CU0022889	CU0020121	
Sample Date		Client Info		23 May 2024	13 Oct 2022	
Machine Age	hrs	Client Info		268	230	
Sample Status				NORMAL	NORMAL	
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.840	0.838	
Fuel Color	text	Visual Screen*	Yllow	LtRed	Pink	
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.3	2.3	
Pensky-Martens Flash Point	°C	ASTM D7215*	52	55	55.9	
SULFUR CONTER	١T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	7	8	
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	166	167	
5% Distillation Point	°C	ASTM D2887*		188	189	
10% Distill Point	°C	ASTM D2887*	201	198	198	
15% Distillation Point	°C	ASTM D2887*		205	204	
20% Distill Point	°C	ASTM D2887*	216	211	211	
30% Distill Point	°C	ASTM D2887*	230	225	224	
40% Distill Point	°C	ASTM D2887*	243	237	236	
50% Distill Point	°C	ASTM D2887*	255	250	248	
60% Distill Point	°C	ASTM D2887*	267	263	262	
70% Distill Point	°C	ASTM D2887*	280	277	275	
80% Distill Point	°C	ASTM D2887*	295	294	292	
85% Distillation Point	°C	ASTM D2887*	0.4.0	306	303	
90% Distill Point	°C	ASTM D2887*	310	318	314	
95% Distillation Point	°C °C	ASTM D2887* ASTM D2887*	341	337	331 351	
Final Boiling Point			-	369		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	36	37	
Cetane Index		ASTM D4737*	<40.0	46	46	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0	0	
Sodium	ppm	ASTM D5185(m)	<0.1	0	0	
Potassium	ppm	ASTM D5185(m)	< 0.1	0	0	
Water	%	ASTM D6304*	< 0.05	0.003	0.004	
ppm Water	ppm	ASTM D6304*	<500	38	46.5	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	408	2085	
Particles >6µm		ASTM D7647	>640	106	477	
Particles >14µm		ASTM D7647	>80	9	12	
Particles >21µm		ASTM D7647	>20	2	2	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>18/16/13	16/14/10	18/16/11	

Contact/Location: Elisia Johnson - CUMMISGEN




# FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
luminum	ppm	ASTM D5185(m)	<0.1	0	0	
lickel	ppm	ASTM D5185(m)	<0.1	0	0	
ead	ppm	ASTM D5185(m)	<0.1	0	0	
anadium	ppm	ASTM D5185(m)	<0.1	0	0	
on	ppm	ASTM D5185(m)	<0.1	0	<1	
Calcium	ppm	ASTM D5185(m)	<0.1	<1	2	
lagnesium	ppm	ASTM D5185(m)	<0.1	0	<1	
hosphorus	ppm	ASTM D5185(m)	<0.1	<1	<1	
linc	ppm	ASTM D5185(m)	<0.1	<1	<1	




Pensky-Martens Flash Point (°C)



Received

Diagnosed

Tested



: 24 Jun 2024 7175 PACIFIC CIRCLE : 26 Jun 2024 MISSISSAUGA, ON : 26 Jun 2024 - Kevin Marson Contact: Elisia Johnson elisia.johnson@cummins.com T: (905)795-0050 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. F: (905)795-9252

Report Id: CUMMISGEN [WCAMIS] 02643847 (Generated: 06/26/2024 08:52:20) Rev: 1

Contact/Location: Elisia Johnson - CUMMISGEN

Page 2 of 2

CA L5T 2A5