


## **OIL ANALYSIS REPORT**

## Area Gary Steacy - G02900 A2406154

Transformer Oil Fluid {not provided} (--- GAL)

DIAGNOSIS



Sample Rating Trend



NORMAL

SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Batch #		Client Info		2024 06 0720		
Department		Client Info		Production		
Sample From		Client Info		Machine		
Production Stage		Client Info		Initial		
Sent to WC		Client Info		06/24/2024		
Sample Number		Client Info		E30002463		
Sample Date		Client Info		24 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	Ν	method	limit/base	current	history1	history2
Water		WC Method	>0.0035	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>125	<1		
Chromium	ppm	ASTM D5185(m)		0		
Nickel	ppm	ASTM D5185(m)		<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>5	<1		
Lead	ppm	ASTM D5185(m)	>30	0		
Copper	ppm	ASTM D5185(m)	>10	<1		
Tin	ppm	ASTM D5185(m)	>2	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		0		
Calcium	ppm	ASTM D5185(m)		0		
Phosphorus	ppm	ASTM D5185(m)		<1		
Zinc	ppm	ASTM D5185(m)		<1		
Sulfur	ppm	ASTM D5185(m)		813		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	0		
Sodium	ppm	ASTM D5185(m)		0		

ppm

ASTM D5185(m) >20

<1

Potassium



## **OIL ANALYSIS REPORT**

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
SAMPLE IMAGES						
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
SAMPLE IMAGES	6	method	limit/base	current	history1 no image	history2 no image
	5	method	limit/base	current		

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Laboratory Environmental 360 Solutions Ltd. CALA Sample No. : E30002463 Received : 26 Jun 2024 640 Victoria Street Lab Number : 02644274 Tested : 26 Jun 2024 Cobourg, ON ISO 17025:2017 Accredited Laboratory Diagnosed Unique Number : 5801813 : 27 Jun 2024 - Tatiana Sorkina CA K9A 5H5 Test Package : TEST (Additional Tests: ICP) Contact: Tatiana Sorkina To discuss this sample report, contact Customer Service at 1-905-372-2251. tsorkina@e360s.ca T: (800)263-3939 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. F: (905)373-4950

Report Id: CHECOB [WCAMIS] 02644274 (Generated: 06/27/2024 07:45:42) Rev: 1

Contact/Location: Tatiana Sorkina - CHECOB Page 2 of 2