


PROBLEM SUMMARY

Gas Compression V650201 GTC 1

Jet Turbine Fluic MOBIL JET OIL II (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use offline filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS Sample Status SEVERE NORMAL NORMAL Particles >4µm ASTM D7647 >2500 **42928** 1750 460 Particles >6µm ASTM D7647 >640 4870 491 132 Particles >14µm ASTM D7647 >80 164 58 14 Particles >21um ASTM D7647 >20 65 21 4 2 Particles >38µm ASTM D7647 >4 **1**5 1 **Oil Cleanliness** ISO 4406 (c) >18/16/13 **423/19/15** 18/16/13 16/14/11 White Metal scalar Visual* NONE VLITE NONE NONE no image no image

PrtFilter


Customer Id: EXXSTJ Sample No.: PP14002073 Lab Number: 02644380 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com



RECOMMENDED ACTIONS								
Action	Status	Date	Done By	Description				
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.				
Resample			?	Resample in 30-45 days to monitor this situation.				
Information Required			?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.				
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.				
Check Dirt Access			?	We advise that you check all areas where contaminants can enter the system.				
Check For Visual Metal			?	We advise that you check for visible metal particles in the oil.				
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.				

HISTORICAL DIAGNOSIS



NORMAL

03 Mar 2024 Diag: Kevin Marson

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable for this fluid. The condition of the oil is suitable for further service.



25 Nov 2023 Diag: Kevin Marson

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable for this fluid. The condition of the oil is suitable for further service.



ISO

06 Aug 2023 Diag: Kevin Marson

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Area Gas Compression V650201 GTC 1

Jet Turbine Fluid MOBIL JET OIL II (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use offline filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

🔺 Wear

Light concentration of visible metal present.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.





Sample Rating Trend


SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP14002073	PP13969618	PP13937659
Sample Date		Client Info		30 May 2024	03 Mar 2024	25 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	NORMAL	NORMAL
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>8	0	0	0
Chromium	ppm	ASTM D5185(m)	>2	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	0	<1
Titanium	ppm	ASTM D5185(m)	>2	<1	0	0
Silver	ppm	ASTM D5185(m)	>2	0	0	<1
Aluminum	ppm	ASTM D5185(m)	>2	0	0	0
Lead	ppm	ASTM D5185(m)	>3	0	0	<1
Copper	ppm	ASTM D5185(m)	>3	0	<1	<1
Tin	ppm	ASTM D5185(m)	>2	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		1	1	1
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		0	<1	<1
Calcium	ppm	ASTM D5185(m)		0	1	2
Phosphorus	ppm	ASTM D5185(m)		2833	2744	3149
Zinc	ppm	ASTM D5185(m)		<1	<1	<1
Sulfur	ppm	ASTM D5185(m)		2	66	4
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>8	1	0	1
Sodium	ppm	ASTM D5185(m)		0	4	5
Potassium	ppm	ASTM D5185(m)	>20	0	<1	0



OIL ANALYSIS REPORT







FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	42928	1750	460
Particles >6µm		ASTM D7647	>640	<u> </u>	491	132
Particles >14µm		ASTM D7647	>80	🔺 164	58	14
Particles >21µm		ASTM D7647	>20	<mark>人</mark> 65	21	4
Particles >38µm		ASTM D7647	>4	4 15	2	1
Particles >71µm		ASTM D7647	>3	5	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	4 23/19/15	18/16/13	16/14/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.03	0.05	0.16	0.28
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE		NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	VLITE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	27.6	25.1	26.9	26.1
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color						
Bottom						

PrtFilter

: PP14002073



: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 ExxonMobil Canada East Ltd. Received : 27 Jun 2024 Hebron-Materials and Repair Coordin, Suite 1000, 100 New Gow Tested : 03 Jul 2024 St. John`s, NL Diagnosed : 03 Jul 2024 - Kevin Marson CA A1C 6K3 Test Package : MAR 2 (Additional Tests: BottomAnalysis, FILTERPATCH, PQ, PRTCOUNT, PrtFilter, TAN Macontact: Liam Maher To discuss this sample report, contact Customer Service at 1-800-268-2131. liam.m.maher@exxonmobil.com T: (709)273-3729 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. E:

Report Id: EXXSTJ [WCAMIS] 02644380 (Generated: 07/03/2024 13:28:11) Rev: 1

CALA

ISO 17025:2017 Accredited Laboratory

Laboratory

Sample No.

Lab Number : 02644380

Unique Number : 5801919

Contact/Location: Liam Maher - EXXSTJ Page 4 of 4

no image

no image