




# OIL ANALYSIS REPORT

Sample Rating Trend



PH



Area

centre énergétique

Machine Id  
**14-1801-03**

Component  
**3 Screw Compressor**

Fluid  
**SULLAIR SULLUBE (500 LTR)**

## DIAGNOSIS

### Recommendation

Échantillonner de nouveau l'équipement au prochain intervalle de vidange afin d'en surveiller la condition.

### Wear

Les taux d'usure de tous les composants sont normaux.

### Contamination

La propreté du système est acceptable pour votre objectif de propreté ISO 4406. La teneur en eau est négligeable. La propreté du système et du fluide est acceptable.

### Fluid Condition

Le AN est acceptable pour ce fluide. L'état de l'huile permet d'en prolonger l'utilisation.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0908997</b>	WC0934036	WC0915602
Sample Date	Client Info		<b>26 Jun 2024</b>	06 May 2024	09 Apr 2024
Machine Age	hrs	Client Info	<b>0</b>	157232	156486
Oil Age	hrs	Client Info	<b>0</b>	7137	6390
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >60	<b>3</b>	3	4
Chromium	ppm	ASTM D5185(m) >4	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185(m) >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185(m) >30	<b>1</b>	<1	1
Tin	ppm	ASTM D5185(m)	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 12	<b>2</b>	3	<1
Barium	ppm	ASTM D5185(m) 500	<b>265</b>	148	256
Molybdenum	ppm	ASTM D5185(m) 0.0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m) 0.0	<b>0</b>	<1	<1
Calcium	ppm	ASTM D5185(m) 8.2	<b>3</b>	3	5
Phosphorus	ppm	ASTM D5185(m) 4.0	<b>&lt;1</b>	<1	0
Zinc	ppm	ASTM D5185(m) 0.1	<b>4</b>	4	5
Sulfur	ppm	ASTM D5185(m) 240	<b>253</b>	327	333
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1






## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	<b>&lt;1</b>	0	0
Sodium	ppm	ASTM D5185(m)	<b>53</b>	25	33
Potassium	ppm	ASTM D5185(m) >20	<b>5</b>	5	7
Water	%	ASTM D6304* >0.5	<b>0.357</b>	0.383	0.081
ppm Water	ppm	ASTM D6304* >5000	<b>3575</b>	3833	818

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>605</b>	1354	458
Particles >6µm	ASTM D7647	>2500	<b>72</b>	253	127
Particles >14µm	ASTM D7647	>320	<b>9</b>	34	19
Particles >21µm	ASTM D7647	>80	<b>3</b>	7	5
Particles >38µm	ASTM D7647	>20	<b>1</b>	0	1
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	1
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>16/13/10</b>	18/15/12	16/14/11

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.06	<b>0.25</b>	0.62	0.62





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.5	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287*		<b>▲ 4.08</b>	▲ 3.32	▲ 2.34
Visc @ 40°C	cSt	ASTM D7279(m)	38.1	<b>40.6</b>	42.7	41.7

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0908997 **Received** : 28 Jun 2024  
**Lab Number** : **02644601** **Tested** : 04 Jul 2024  
**Unique Number** : 5802140 **Diagnosed** : 04 Jul 2024 - Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: KF, pH, TAN Man )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**RTA - UGB**  
 C.P. 900  
 Ville de la Baie, QC  
 CA G7B 4G9  
 Contact: Alcan Epc  
 mathieu.tremblay2@riotinto.com  
 T: (418)697-9568  
 F: (418)697-9550