OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id
CATERPILLAR 980H 2230704
Component
Front Right Planetary
Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0914638**	---	---
Sample Date		Client Info		**25 Jun 2024**	---	---
Machine Age	hrs	Client Info		**27735**	---	---
Oil Age	hrs	Client Info		**0**	---	---
Oil Changed		Client Info		**Not Changd**	---	---
Sample Status				**NORMAL**	---	---

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.2	**NEG**	---	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>500	**15**	---	---
Chromium	ppm	ASTM D5185(m)	>10	**0**	---	---
Nickel	ppm	ASTM D5185(m)	>10	**<1**	---	---
Titanium	ppm	ASTM D5185(m)		**0**	---	---
Silver	ppm	ASTM D5185(m)		**0**	---	---
Aluminum	ppm	ASTM D5185(m)	>25	**1**	---	---
Lead	ppm	ASTM D5185(m)	>25	**0**	---	---
Copper	ppm	ASTM D5185(m)	>75	**2**	---	---
Tin	ppm	ASTM D5185(m)	>10	**0**	---	---
Antimony	ppm	ASTM D5185(m)	>5	**0**	---	---
Vanadium	ppm	ASTM D5185(m)		**0**	---	---
Beryllium	ppm	ASTM D5185(m)		**0**	---	---
Cadmium	ppm	ASTM D5185(m)		**0**	---	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		**91**	---	---
Barium	ppm	ASTM D5185(m)		**0**	---	---
Molybdenum	ppm	ASTM D5185(m)		**6**	---	---
Manganese	ppm	ASTM D5185(m)		**<1**	---	---
Magnesium	ppm	ASTM D5185(m)		**47**	---	---
Calcium	ppm	ASTM D5185(m)		**3372**	---	---
Phosphorus	ppm	ASTM D5185(m)		**1081**	---	---
Zinc	ppm	ASTM D5185(m)		**1345**	---	---
Sulfur	ppm	ASTM D5185(m)		**6329**	---	---
Lithium	ppm	ASTM D5185(m)		**<1**	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>75	**10**	---	---
Sodium	ppm	ASTM D5185(m)		**<1**	---	---
Potassium	ppm	ASTM D5185(m)	>20	**<1**	---	---

OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	---	---
Yellow Metal	scalar	Visual*	NONE	**NONE**	---	---
Precipitate	scalar	Visual*	NONE	**NONE**	---	---
Silt	scalar	Visual*	NONE	**NONE**	---	---
Debris	scalar	Visual*	NONE	**VLITE**	---	---
Sand/Dirt	scalar	Visual*	NONE	**NONE**	---	---
Appearance	scalar	Visual*	NORML	**NORML**	---	---
Odor	scalar	Visual*	NORML	**NORML**	---	---
Emulsified Water	scalar	Visual*	>0.2	**NEG**	---	---
Free Water	scalar	Visual*		**NEG**	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		**60.7**	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				*no image*	*no image*
Bottom				*no image*	*no image*

GRAPHS

















ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0914638 **Received** : 28 Jun 2024
Lab Number : 02644649 **Tested** : 28 Jun 2024
Unique Number : 5802188 **Diagnosed** : 28 Jun 2024 - Wes Davis
Test Package : MOB 1

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

E.C. KING CONTRACTING
2125 - 20TH AVENUE EAST
OWEN SOUND, ON
CA N4K 5P7
Contact: Daniel Fleet
daniel.fleet@millergroup.ca
T:
F: (519)371-2783