

COOLANT REPORT



Machine Id

KOHLER JC Fresh Farms

Component Coolant Fluid CONVENTIONAL COOLANT (--- GAL)

DIAGNOSIS

Recommendation

We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer's recommendations. Resample at the next service interval to monitor.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition


The reserve alkalinity of this fluid is lower than acceptable. The low nitrite level indicates reduced cavitation protection which leads to corrosion and ammonia formation. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0849191		
Sample Date		Client Info		17 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
PHYSICAL TEST F	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR		UNK		
Specific Gravity		ASTM D1298*		1.070		
рН	Scale 0-14	ASTM D1287*	9.5	8.22		
Nitrites	ppm	Alcan Test Kit*	1500	<u> </u>		
Reserve Alkalinity	Scale 0-20	ASTM D1121*	8.5	6 .1		
Percentage Glycol	%	ASTM D3321*	50	52.6		
Freezing Point	°C	ASTM D3321*	-40	-40		
Carboxylate						
CORROSION INH	BITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		21		
Phosphorus	ppm	ASTM D5185(m)		855		
Boron	ppm	ASTM D5185(m)		122		
Molybdenum	ppm	ASTM D5185(m)		30		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	0		
Aluminum	ppm	ASTM D5185(m)	>10	0		
Copper	ppm	ASTM D5185(m)	>10	4		
Lead	ppm	ASTM D5185(m)	>10	0		
Tin	ppm	ASTM D5185(m)	>10	0		
Silver	ppm	ASTM D5185(m)	>10	<1		
Zinc	ppm	ASTM D5185(m)		1		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		1612		
Potassium	ppm	ASTM D5185(m)		1499		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	4		
Magnesium	ppm	ASTM D5185(m)	>40	<1		
Hardness	mg/L CaCO3	In-house*	<75	12		



COOLANT REPORT







 Accredited Laboratory
 Unique Number
 : 5802251
 Diagnosed
 : 02 Jul 2024 - Kevin Marson

 Test Package
 : COOL (Additional Tests: GlycolType)

 To discuss this sample report, contact Customer Service at 1-800-268-2131.

 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

 Validity of results and interpretation are based on the sample and information as supplied.
 CF Industrial Products Inc. 1928 Road 3 East Kingsville, ON CA N9Y 2E5 Contact: Dan Hammond danh@cfgroups.com T: (519)564-2241 F: (519)322-2916

Report Id: CFILEA [WCAMIS] 02644712 (Generated: 07/02/2024 07:57:38) Rev: 1

CALA

ISO 17025:2017

Submitted By: Dan Hammond Page 2 of 2