

OIL ANALYSIS REPORT

Area 6 Calender Line 39-0034 South Cooling Mixer

Gearbox Fluid MOBIL GLYGOYLE 30 (70 LTR)

DIAGNOSIS

A Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

🔺 Wear

Chromium and titanium ppm levels are marginal. Light concentration of visible metal present. Gear wear is indicated.

Contamination

There is a moderate concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The oil is no longer serviceable as a result of the abnormal and/or severe wear.


	TER
h n bill .	
li n. lalat .	


Sample Rating Trend


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0926976	WC0892261	WC0867513
Sample Date		Client Info		06 Jun 2024	20 Mar 2024	04 Jan 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>200	65	67	39
Chromium	ppm	ASTM D5185(m)	>15	🔺 16	14	14
Nickel	ppm	ASTM D5185(m)	>15	1	1	1
Titanium	ppm	ASTM D5185(m)		<mark>/</mark> 31	18	10
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>25	2	2	1
Lead	ppm	ASTM D5185(m)	>100	<1	<1	1
Copper	ppm	ASTM D5185(m)	>200	42	43	38
Tin	ppm	ASTM D5185(m)	>25	6	6	5
Antimony	ppm	ASTM D5185(m)	>5	14	12	9
Vanadium	ppm	ASTM D5185(m)		<1	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		18	17	15
Barium	ppm	ASTM D5185(m)		5	3	3
Molybdenum	ppm	ASTM D5185(m)		1	0	<1
Manganese	ppm	ASTM D5185(m)		<1	0	0
Magnesium	ppm	ASTM D5185(m)		3	2	2
Calcium	ppm	ASTM D5185(m)		341	305	263
Phosphorus	ppm	ASTM D5185(m)		1103	1114	1143
Zinc	ppm	ASTM D5185(m)		5	5	4
Sulfur	ppm	ASTM D5185(m)		129	306	161
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	12	9	9
Sodium	ppm	ASTM D5185(m)		7	5	3
Potassium	ppm	ASTM D5185(m)	>20	4	2	6
Water	%	ASTM D6304*	>0.2	A 0.287		0.126
ppm Water	ppm	ASTM D6304*	>2000	A 2875		1266




OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE		VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	VLITE	NONE
Debris	scalar	Visual*	NONE	🔺 light	LIGHT	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	🔺 HAZY	NORML	HAZY
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	224	244	242	242
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						
Bottom						
PrtFilter				38 .		



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CANADIAN GENERAL TOWER LTD. CALA Sample No. : WC0926976 Received : 02 Jul 2024 52 MIDDLETON STREET, P.O. BOX 160 Lab Number : 02644977 Tested : 03 Jul 2024 CAMBRIDGE, ON ISO 17025:2017 Accredited Laboratory Unique Number : 5802516 Diagnosed : 04 Jul 2024 - Kevin Marson CA N1S 2R4 Test Package : IND 1 (Additional Tests: BottomAnalysis, FILTERPATCH, KF) Contact: Bob Abell To discuss this sample report, contact Customer Service at 1-800-268-2131. bob.abell@cgtower.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (519)623-1630 Validity of results and interpretation are based on the sample and information as supplied. F: (519)623-7018

Report Id: CAN52CAM [WCAMIS] 02644977 (Generated: 07/04/2024 05:49:40) Rev: 1

Contact/Location: Bob Abell - CAN52CAM

Page 2 of 2