





PROBLEM SUMMARY

Sample Rating Trend



Machine Id
COILER COMPRESSOR (PLS082)
 Component
 Reciprocating Compressor
 Fluid
 SHELL TURBO T ISO 68 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Iron	ppm	ASTM D5185(m)	>50	▲ 311	27	27
Copper	ppm	ASTM D5185(m)	>50	▲ 186	33	13
Particles >4µm		ASTM D7647	>10000	▲ 181478	▲ 130276	▲ 85033
Particles >6µm		ASTM D7647	>2500	▲ 145921	▲ 52790	▲ 19475
Particles >14µm		ASTM D7647	>320	▲ 20314	▲ 1380	▲ 851
Particles >21µm		ASTM D7647	>80	▲ 1723	▲ 325	▲ 183
Particles >38µm		ASTM D7647	>20	▲ 49	16	4
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ 25/24/22	▲ 24/23/18	▲ 24/21/17
Acid Number (AN)	mg KOH/g	ASTM D974*	.05	▲ 0.93	0.29	0.29

Customer Id: ALGSSM
 Sample No.: WC0813589
 Lab Number: 02645483
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.

HISTORICAL DIAGNOSIS

ISO



04 Jun 2023 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



ISO



02 Nov 2022 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >6µm are abnormally high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id

COILER COMPRESSOR (PLS082)

Component

Reciprocating Compressor

Fluid

SHELL TURBO T ISO 68 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

Copper and iron ppm levels are severe.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is above the recommended limit. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0813589	WC0714520	WC0714618
Sample Date	Client Info		01 Jul 2024	04 Jun 2023	02 Nov 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	---	---
Iron	ppm	ASTM D5185(m) >50	▲ 311	27	27
Chromium	ppm	ASTM D5185(m) >10	3	0	0
Nickel	ppm	ASTM D5185(m)	<1	0	0
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	0	0
Aluminum	ppm	ASTM D5185(m) >25	2	<1	<1
Lead	ppm	ASTM D5185(m) >25	10	2	2
Copper	ppm	ASTM D5185(m) >50	▲ 186	33	13
Tin	ppm	ASTM D5185(m) >15	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	2	<1	0
Magnesium	ppm	ASTM D5185(m)	<1	0	0
Calcium	ppm	ASTM D5185(m)	2	0	0
Phosphorus	ppm	ASTM D5185(m)	11	5	8
Zinc	ppm	ASTM D5185(m)	12	2	<1
Sulfur	ppm	ASTM D5185(m)	161	166	243
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	6	<1	<1
Sodium	ppm	ASTM D5185(m)	6	<1	0
Potassium	ppm	ASTM D5185(m) >20	8	2	<1
Water	%	ASTM D6304* >0.1	0.009	0.002	0.002
ppm Water	ppm	ASTM D6304* >1000	100	23.3	22.2

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 181478	▲ 130276	▲ 85033
Particles >6µm	ASTM D7647	>2500	▲ 145921	▲ 52790	▲ 19475
Particles >14µm	ASTM D7647	>320	▲ 20314	▲ 1380	▲ 851
Particles >21µm	ASTM D7647	>80	▲ 1723	▲ 325	▲ 183
Particles >38µm	ASTM D7647	>20	▲ 49	16	4
Particles >71µm	ASTM D7647	>4	4	1	0

Oil Cleanliness

ISO 4406 (c) >20/18/15 ▲ 25/24/22 ▲ 24/23/18 ▲ 24/21/17



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	.05	▲ 0.93	0.29	0.29






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	VLITE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	LIGHT	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68	66.3	63.5	62.0

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0813589
Lab Number : 02645483
Unique Number : 5803022
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount, TAN Man)

ALGOMA STEEL INC. - STORES DEPT.
 301 WALLACE TERRACE
 SAULT STE MARIE, ON
 CA P6C 1K8
 Contact: Algoma Reliability
 algomareliability@algoma.com
 T: (705)206-1059
 F: (705)945-3585

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.