OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
SAB1
Machine Id
SAB1 G6
Component
Turbine Bearing
Fluid
ESSO TERESSO ISO 46 (150 LTR)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition
The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0933973**	WC0812558	WC0642846
Sample Date		Client Info		**03 Jul 2024**	15 May 2024	21 Dec 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	SEVERE	ABNORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>2	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		**0**	0	0
Iron	ppm	ASTM D5185(m)	>7	**4**	▲ 10	1
Chromium	ppm	ASTM D5185(m)	>2	**0**	0	0
Nickel	ppm	ASTM D5185(m)	>2	**<1**	0	0
Titanium	ppm	ASTM D5185(m)		**0**	0	0
Silver	ppm	ASTM D5185(m)		**0**	0	0
Aluminum	ppm	ASTM D5185(m)	>2	**<1**	0	<1
Lead	ppm	ASTM D5185(m)	>33	**3**	● 11	2
Copper	ppm	ASTM D5185(m)	>3	**<1**	<1	<1
Tin	ppm	ASTM D5185(m)	>6	**0**	<1	0
Antimony	ppm	ASTM D5185(m)		**0**	<1	0
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	**<1**	0	0
Barium	ppm	ASTM D5185(m)		**0**	0	0
Molybdenum	ppm	ASTM D5185(m)	0	**0**	0	0
Manganese	ppm	ASTM D5185(m)		**0**	0	0
Magnesium	ppm	ASTM D5185(m)	0	**0**	2	0
Calcium	ppm	ASTM D5185(m)	0	**2**	11	<1
Phosphorus	ppm	ASTM D5185(m)	2.4	**2**	2	3
Zinc	ppm	ASTM D5185(m)	0	**2**	2	<1
Sulfur	ppm	ASTM D5185(m)		**601**	616	709
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>20	**1**	<1	5
Sodium	ppm	ASTM D5185(m)		**0**	1	0
Potassium	ppm	ASTM D5185(m)	>20	**0**	<1	<1

OIL ANALYSIS REPORT

Particle Count



Particle Trend



Acid Number



Viscosity @ 40°C



PQ



FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ **41551**	▲ 134041	▲ 25335
Particles >6µm		ASTM D7647	>1300	● **2052**	▲ 46308	● 1527
Particles >14µm		ASTM D7647	>160	**10**	▲ 554	12
Particles >21µm		ASTM D7647	>40	**3**	39	4
Particles >38µm		ASTM D7647	>10	**0**	1	1
Particles >71µm		ASTM D7647	>3	**0**	1	0
Oil Cleanliness		ISO 4406 (c)	>20/17/14	▲ **23/18/10**	▲ 24/23/16	▲ 22/18/11

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	**0.05**	0.07	0.07

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	NONE
Silt	scalar	Visual*	NONE	**VLITE**	LIGHT	NONE
Debris	scalar	Visual*	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	VLITE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>2	**NEG**	NEG	NEG
Free Water	scalar	Visual*		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	**45.3**	45.7	45.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0933973
Lab Number : 02645509
Unique Number : 5803048
Test Package : IND 2 (Additional Tests: PQ, PrtCount, TAN Man)
Received : 04 Jul 2024
Tested : 05 Jul 2024
Diagnosed : 05 Jul 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

Ontario Power Generation
NIAGARA PLANT GROUP,, 14000 NIAGARA PKWY
NIAGARA ON THE LAKE, ON
CA L0S 1J0
Contact: Michael Brochu
mike.brochu@opg.com
T: (905)357-0322
F: (905)374-5466