




# PROBLEM SUMMARY

## Sample Rating Trend






ISO



Machine Id  
**SEW STACKER #8 HOIST**  
 Component  
**Hoist**  
 Fluid  
**MOBIL SHC 626 (52 LTR)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>5000	▲ 63577	▲ 29262	▲ 135682
Particles >6µm	ASTM D7647	>1300	▲ 3997	● 1552	▲ 36721
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 23/19/12	▲ 22/18/12	▲ 24/22/15
Visc @ 40°C	cSt	ASTM D7279(m)	▲ 29.0	▲ 32.8	32.8

Customer Id: CON266MIS  
 Sample No.: WC0871099  
 Lab Number: 02645612  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

DIRT



**22 Nov 2021 Diag: Kevin Marson**

Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. All component wear rates are normal. Silicon ppm levels are abnormally high. Particles >4µm are abnormally high. Particles >6µm are notably high. Elemental level of silicon (Si) above normal indicating ingress of seal material. Viscosity of sample indicates oil is within ISO 32 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



ISO



**28 Oct 2019 Diag: Wes Davis**

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >4µm are severely high. Particles >14µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



ISO



**16 May 2018 Diag: Kevin Marson**

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Particles >14µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**SEW STACKER #8 HOIST**  
 Component  
**Hoist**  
 Fluid  
**MOBIL SHC 626 (52 LTR)**

### DIAGNOSIS

#### ▲ Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### ▲ Fluid Condition

Viscosity of sample indicates oil is within ISO 32 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0871099</b>	WC0636146	WC0385659
Sample Date	Client Info		<b>17 Jun 2024</b>	22 Nov 2021	28 Oct 2019
Machine Age	yrs	Client Info	<b>8</b>	0	5639
Oil Age	yrs	Client Info	<b>3</b>	0	5639
Oil Changed	Client Info		<b>Changed</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ABNORMAL	SEVERE

### CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.05	<b>NEG</b>	NEG	NEG

### WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	<b>6</b>	6	14
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	0	<1
Lead	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	0
Copper	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Barium	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185(m)		<b>0</b>	0	2
Calcium	ppm	ASTM D5185(m)		<b>24</b>	95	951
Phosphorus	ppm	ASTM D5185(m)		<b>449</b>	507	541
Zinc	ppm	ASTM D5185(m)		<b>3</b>	<1	2
Sulfur	ppm	ASTM D5185(m)		<b>57</b>	31	156
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

### CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<b>0</b>	20	2
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1

### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>63577</b>	29262	135682
Particles >6µm	ASTM D7647	>1300	<b>3997</b>	1552	36721
Particles >14µm	ASTM D7647	>160	<b>28</b>	27	258
Particles >21µm	ASTM D7647	>40	<b>7</b>	5	43
Particles >38µm	ASTM D7647	>10	<b>2</b>	0	1
Particles >71µm	ASTM D7647	>3	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>23/19/12</b>	22/18/12	24/22/15









# OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.41</b>	0.62	0.404

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	69.9	<b>▲ 29.0</b>	▲ 32.8	32.8

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						
PrtFilter	no image			no image	no image	no image



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0871099      **Received** : 04 Jul 2024  
**Lab Number** : **02645612**      **Tested** : 08 Jul 2024  
**Unique Number** : 5803151      **Diagnosed** : 08 Jul 2024 - Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: Bottom, FilterPatch )

**CONESTOGA COLD STORAGE**  
 2660 MEADOWPINE BLVD., DOOR 57, CALL EXT. 2317  
 MISSISSAUGA, ON  
 CA L5N 7E6  
 Contact: Jeremy Koziol  
 jkoziol@coldstorage.com  
 T: (519)748-4086  
 F: (905)567-1844

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.