


PROBLEM SUMMARY

Sample Rating Trend

Area 106 Mill MORGOIL (MAIN) LUBE (PLS018) (S/N 1000000777) Gear Lube System

Fluid {not provided} (--- GAL)



RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you change the oil. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.


Customer Id: ALGSSM Sample No.: WC0689915 Lab Number: 02645660 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com



PROBLEMATIC TEST RESULTS							
Sample Status				SEVERE	SEVERE	SEVERE	
Water	%	ASTM D6304*	>0.1	1.536	1 .552	1 .533	
ppm Water	ppm	ASTM D6304*	>1000	15366	1 5524	1 5338.7	
Precipitate	scalar	Visual*	NONE	A MODER	NONE	NONE	
Emulsified Water	scalar	Visual*	>0.1	<u> 1%</u>	1 %	1 %	
Free Water	scalar	Visual*		<u> </u>	NEG	▲ >10%	

RECOMMENDED A	CHONS			
Action	Status	Date	Done By	Description
Change Fluid			?	We recommend that you change the oil.
Resample			?	We recommend an early resample to monitor this condition.
Alert			?	Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment.
Information Required			?	Please specify the brand, type, and viscosity of the oil on your next sample. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Water Access			?	We advise that you check for the source of water entry.
Check Seals			?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

ANACNIDED ACTION



01 Jun 2024 Diag: Kevin Marson

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We recommend either performing an oil change or oil filtration. We cannot recommend a pecific action as we have limited information with regards to reservoir capacity and/or lubricant type. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.



02 Jun 2023 Diag: Kevin Marson



Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We recommend either performing an oil change or oil filtration. We cannot recommend specific action as we have limited information with regards to reservoir capacity and/or lubricant type. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.All component wear rates are normal. There is a high concentration of water present in the oil. Excessive free water present. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

26 May 2023 Diag: Kevin Marson



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. There is a moderate concentration of water present in the oil. Excessive free water present. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.







OIL ANALYSIS REPORT

Area **106 MIII** Machine Id MORGOIL (MAIN) LUBE (PLS018) (S/N 1000000777)

Gear Lube System

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you change the oil. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a high concentration of water present in the oil. Free water present.

Fluid Condition


The white residue present in the sample is oil additive precipitate. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.





SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0689915	WC0752275	WC0714536
Sample Date		Client Info		01 Jul 2024	01 Jun 2024	02 Jun 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	N/A
Sample Status				SEVERE	SEVERE	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>150	66	66	66
Chromium	ppm	ASTM D5185(m)	>10	<1	0	0
Nickel	ppm	ASTM D5185(m)	>10	<1	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>25	<1	10	<1
Lead	ppm	ASTM D5185(m)	>100	0	0	0
Copper	ppm	ASTM D5185(m)	>50	2	2	2
Tin	ppm	ASTM D5185(m)	>10	4	3	3
Antimony	ppm	ASTM D5185(m)	>5	0	3	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1	<1	<1
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		<1	0	0
Magnesium	ppm	ASTM D5185(m)		<1	1	<1
Calcium	ppm	ASTM D5185(m)		2	2	0
Phosphorus	ppm	ASTM D5185(m)		55	59	66
Zinc	ppm	ASTM D5185(m)		1	3	<1
Sulfur	ppm	ASTM D5185(m)		2975	3053	3731
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	2	1	3
Sodium	ppm	ASTM D5185(m)		<1	2	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Water	%	ASTM D6304*	>0.1	1.536	1.552	1 .533
ppm Water	ppm	ASTM D6304*	>1000	15366	▲ 15524	▲ 15338.7
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		1.12	0.38	0.31



OIL ANALYSIS REPORT








Dec31/

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	🔺 MODER	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	MODER	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	🔺 WGOIL
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	<u> </u>	1 %	<u> </u>
Free Water	scalar	Visual*		<u> </u>	NEG	▲ >10%
FLUID PROPERT	IES	method	limit/base	current	history1	history2
FLUID PROPERT Visc @ 40°C	CIES cSt	method ASTM D7279(m)	limit/base	current 482	history1 470	history2 472
	cSt		limit/base limit/base			
Visc @ 40°C	cSt	ASTM D7279(m)		482	470	472



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 ALGOMA STEEL INC. - STORES DEPT. CALA Sample No. : WC0689915 Received : 04 Jul 2024 301 WALLACE TERRACE Lab Number : 02645660 Tested : 08 Jul 2024 SAULT STE MARIE, ON ISO 17025:2017 Accredited Laboratory Unique Number : 5803199 Diagnosed : 08 Jul 2024 - Kevin Marson CA P6C 1K8 Test Package : IND 2 (Additional Tests: Bottom, KF, TAN Man) Contact: Algoma Reliability algomareliability@algoma.com To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (705)206-1059 Validity of results and interpretation are based on the sample and information as supplied. F: (705)945-3585

Report Id: ALGSSM [WCAMIS] 02645660 (Generated: 07/08/2024 20:06:04) Rev: 1

Contact/Location: Maintenance Technology - Algoma Reliability - ALGSSM