

COOLANT REPORT

Sample Rating Trend



Machine Id

MERCEDES C7-A

Component Coolant

Fluid VALVOLINE ZEREX G-05 ANTI-FREEZE (--- GAL)

DIAGNOSIS

Recommendation

The fluid is suitable for further service. Resample at the next service interval to monitor.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition


The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0955158	WC0891339	
Sample Date		Client Info		04 Jul 2024	03 Jan 2024	
Machine Age	hrs	Client Info		2866	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	ABNORMAL	
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR		UNK		
Specific Gravity		ASTM D1298*	1.060	1.070	1.073	
рН	Scale 0-14	ASTM D1287*	8.0	7.25	7.26	
Nitrites	ppm	Alcan Test Kit*		1240	1120	
Reserve Alkalinity	Scale 0-20	ASTM D1121*	10.0	7.3	7.6	
Percentage Glycol	%	ASTM D3321*	50	52.3	54.7	
Freezing Point	°C	ASTM D3321*	-36	-40	-45	
Carboxylate						
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	240	50	41	
Phosphorus	ppm	ASTM D5185(m)	0	18	12	
Boron	ppm	ASTM D5185(m)		1526	1627	
Molybdenum	ppm	ASTM D5185(m)		0	<1	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	0	0	
Aluminum	ppm	ASTM D5185(m)	>10	4	2	
Copper	ppm	ASTM D5185(m)	>10	7	1 9	
Lead	ppm	ASTM D5185(m)	>10	0	0	
Tin	ppm	ASTM D5185(m)	>10	0	0	
Silver	ppm	ASTM D5185(m)	>10	0	<1	
Zinc	ppm	ASTM D5185(m)		<1	<1	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		5926	9845	
Potassium	ppm	ASTM D5185(m)		205	613	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	4	4	
Magnesium	ppm	ASTM D5185(m)	>40	1	2	
Hardness	mg/L CaCO3	In-house*	<75	14	15	



COOLANT REPORT







 Iso 17025:2017
 Lab Number
 : 02645991
 Tested
 : 08 Jul 2024

 Accredited Laboratory
 Unique Number
 : 5811543
 Diagnosed
 : 08 Jul 2024 - Kevin Marson

 To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

 Validity of results and interpretation are based on the sample and information as supplied.

Received

: 05 Jul 2024

: WC0955158

3110 Albion Road North Ottawa, ON CA K1V 9V9 Contact: Glenn Skilton Glenn.Skilton@atkinsrealis.com T: (613)907-7100 F:

Report Id: TRA310OTT [WCAMIS] 02645991 (Generated: 07/08/2024 18:53:45) Rev: 1

CALA

Laboratory

Sample No.

Contact/Location: Glenn Skilton - TRA310OTT