








# OIL ANALYSIS REPORT











FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	<b>13.3</b>	---	---
Base Number (BN)	mg KOH/g	ASTM D2896*	8.5	<b>7.71</b>	---	---

VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	---	---
Free Water	scalar	Visual*		<b>NEG</b>	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	14.4	<b>13.8</b>	---	---

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0944083      **Received** : 08 Jul 2024  
**Lab Number** : **02646197**      **Tested** : 09 Jul 2024  
**Unique Number** : 5811749      **Diagnosed** : 09 Jul 2024 - Wes Davis  
**Test Package** : MOB 2

**GENREP LIMITED**  
 25 GIFFORD STREET  
 NEPEAN, ON  
 CA K2E 7S3  
 Contact: Carmen Lavryssen  
 servicedesk@genrep.com  
 T: (613)225-9244  
 F: (613)225-4690

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.