

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

9 Component Air Compressor

Fluid INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP	PP	WC00229873
Sample Date		Client Info		29 Jun 2024	08 Apr 2024	09 May 1995
Machine Age	hrs	Client Info		0	0	-1
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info	N/A		N/A	
Sample Status			NORMAL		NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	
Iron	ppm	ASTM D5185(m)	>50	<1	0	<1
Chromium	ppm	ASTM D5185(m)	>4	0	0	0
Nickel	ppm	ASTM D5185(m)	>4	<1	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>10	0	0	0
Lead	ppm	ASTM D5185(m)		0	0	<1
Copper	ppm	ASTM D5185(m)	>40	<1	<1	2
Tin	ppm	ASTM D5185(m)	>5	0	0	<1
Antimony	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	2	<1	<1
Barium	ppm	ASTM D5185(m)	500	811	872	
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	
Magnesium	ppm	ASTM D5185(m)	0	<1	0	<1
Calcium	ppm	ASTM D5185(m)	0	1	<1	67
Phosphorus	ppm	ASTM D5185(m)	20	<1	0	341
Zinc	ppm	ASTM D5185(m)	0	1	1	391
Sulfur	ppm	ASTM D5185(m)	200	208	229	
Lithium	ppm	ASTM D5185(m)		<1	<1	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	6	0	<1
Sodium	ppm	ASTM D5185(m)		1	1	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	1	<1
Water	%	ASTM D6304*	>0.6	0.215	0.001	
ppm Water	ppm	ASTM D6304*	>6000	2153	3	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		0.03	0.01	



OIL ANALYSIS REPORT



VISUAL		mathad	limit/bass	ourroot	biotoput	biotor
		method	limit/base	current	history1	history
White Metal		isual*	NONE	NONE	NONE	
Yellow Metal		isual*	NONE	NONE	NONE	
Precipitate		isual*	NONE	NONE	NONE	
Silt		isual*	NONE	NONE	NONE	
Debris	scalar V	isual*	NONE	NONE	VLITE	
Sand/Dirt	scalar V	isual*	NONE	NONE	VLITE	
Appearance	scalar V	isual*	NORML	NORML	NORML	
Odor	scalar V	isual*	NORML	NORML	NORML	
Emulsified Water	scalar V	isual*	>0.6	NEG	NEG	
Free Water	scalar V	isual*		NEG	NEG	
FLUID PROPERTI	ES I	method	limit/base	current	history1	history
Visc @ 40°C	cSt AS	STM D7279(m)	49.4	49.1	49.0	65.4
SAMPLE IMAGES	1	method	limit/base	current	history1	history
Color						no imag
Bottom						no imag
GRAPHS						
Ferrous Alloys				PQ		
10 iron			220	T		
o - chromium			200	Severe		
E 6			180			
1			160			
2						
Nov4/92	Apr8/24		140 +72/6			
May	Apri		42/67 120			
Non-ferrous Metals			100	Abnormal - o		
10 T			80			
8 - copper			60	-		
E 6			40			
[□] 4						
2			20	1		
32 32	24		0 24			
Nov4/92 May9/95	Apr8/24		Jun29/24	Apr8/24		
Viscosity @ 40°C				Acid Number		
⁷⁰ 65			(0,2,50 (0,100 km) (0,100 km) (0,500 km) (0,	Severe	1	
Abnormal			Q 2.00	†		
⊖ 60 € 55 bhomal			£ 1.50 ق 1.00	Abnormal	1	
් 50 . යුඩින ොmal				I		
45 - Severe 40						
Nov4/92	Apr8/24 -		Jun29/24	Nov4/92 -	May9/95 -	
Nov	Apr		Jun2	Nov	May	
y : WearCheck - C8-1175 b. : PP ier : 02646716 ber : 5812268	Appleby Li Receive Tested Diagnos	d : 09 : 12	gton, ON L7L Jul 2024 Jul 2024 Jul 2024 - Kevi		1 CARLING	ON TOROI GVIEW DF ORONTO, CA M9W

Test Package : IND 2 (Additional Tests: KF) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Report Id: MOLETO [WCAMIS] 02646716 (Generated: 07/12/2024 10:06:14) Rev: 1

CALA

ISO 17025:2017 Accredited Laboratory

F: Contact/Location: Heath Bagby - MOLETO Page 2 of 2

heath.bagby@molsoncoors.com

Т: