







PROBLEM SUMMARY

Area
 2 Phoenix/003 Flare Gas/C Compressor/102 Flare Gas
 Machine Id
N/A 03C102 SCREW
 Component
Screw Compressor
 Fluid
PETRO CANADA HYDREX AW 46 (2000 LTR)

Sample Rating Trend



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>10000	▲ 70568	▲ 57192	▲ 82565
Particles >6µm	ASTM D7647	>2500	▲ 22498	▲ 14748	▲ 23753
Particles >14µm	ASTM D7647	>320	▲ 1764	▲ 653	▲ 1630
Particles >21µm	ASTM D7647	>80	▲ 479	▲ 228	▲ 426
Particles >38µm	ASTM D7647	>20	▲ 41	▲ 44	12
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 23/22/18	▲ 23/21/17	▲ 24/22/18
Appearance	scalar	Visual*	▲ WGOIL	NORML	▲ WGOIL
Free Water	scalar	Visual*	▲ 1%	NEG	▲ 1%
Visc @ 40°C	cSt	ASTM D7279(m)	▲ 7.2	47.3	46.2

Customer Id: PETMIS
 Sample No.: WC0957451
 Lab Number: 02646723
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We advise an early resample to confirm this situation.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit. NOTE: We recommend using IND 3 test kits,

HISTORICAL DIAGNOSIS



30 Oct 2023 Diag: Kevin Marson

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



27 Jul 2023 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. Free water present. Moderate concentration of visible dirt/debris present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



19 Feb 2023 Diag: Kevin Marson


Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. The fluid was specified as PETRO CANADA HYDREX AW 46, however, a fluid match indicates that this fluid is ISO 46 Refrigeration Compressor Oil. Please confirm the oil type and grade on your next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
2 Phoenix/003 Flare Gas/C Compressor/102 Flare Gas
 Machine Id
N/A 03C102 SCREW
 Component
Screw Compressor
 Fluid
PETRO CANADA HYDREX AW 46 (2000 LTR)

DIAGNOSIS

▲ Recommendation

Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Component wear rates appear to be normal (unconfirmed).

▲ Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. There is a moderate concentration of water present in the oil. Free water present.

▲ Fluid Condition

Viscosity of sample indicates oil is within ISO 7 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0957451	WC0873659	WC0841306
Sample Date	Client Info		02 Jul 2024	30 Oct 2023	27 Jul 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	---	---
Iron	ppm	ASTM D5185(m) >60	2	2	1
Chromium	ppm	ASTM D5185(m) >4	0	0	0
Nickel	ppm	ASTM D5185(m)	<1	0	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	<1	0
Aluminum	ppm	ASTM D5185(m) >5	0	0	<1
Lead	ppm	ASTM D5185(m) >10	0	<1	0
Copper	ppm	ASTM D5185(m) >30	0	<1	<1
Tin	ppm	ASTM D5185(m) >15	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	0	<1	0
Barium	ppm	ASTM D5185(m) 0	0	<1	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m) 0	0	0	0
Magnesium	ppm	ASTM D5185(m) 0	<1	0	<1
Calcium	ppm	ASTM D5185(m) 50	<1	2	8
Phosphorus	ppm	ASTM D5185(m) 330	249	12	13
Zinc	ppm	ASTM D5185(m) 430	1	12	13
Sulfur	ppm	ASTM D5185(m) 760	16	682	611
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	4	<1	1
Sodium	ppm	ASTM D5185(m)	0	<1	0
Potassium	ppm	ASTM D5185(m) >20	0	0	<1
Water	%	ASTM D6304* >0.1	0.010	0.00	0.003
ppm Water	ppm	ASTM D6304* >1000	105	0.00	39.3

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 70568	▲ 57192	▲ 82565
Particles >6µm	ASTM D7647	>2500	▲ 22498	▲ 14748	▲ 23753
Particles >14µm	ASTM D7647	>320	▲ 1764	▲ 653	▲ 1630
Particles >21µm	ASTM D7647	>80	▲ 479	▲ 228	▲ 426
Particles >38µm	ASTM D7647	>20	▲ 41	▲ 44	12
Particles >71µm	ASTM D7647	>4	3	● 9	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 23/22/18	▲ 23/21/17	▲ 24/22/18



OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.70	0.01	0.03	0.07

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE	▲ LTMOD
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	VLITE
Appearance	scalar	Visual*	NORML	▲ WGOIL	NORML	▲ WGOIL
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	.2%	.2%	.2%
Free Water	scalar	Visual*		▲ 1%	NEG	▲ 1%

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.4	▲ 7.2	47.3	46.2

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color			
Bottom			
PrtFilter	no image	no image	



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0957451 **Received** : 09 Jul 2024
Lab Number : **02646723** **Tested** : 15 Jul 2024
Unique Number : 5812275 **Diagnosed** : 15 Jul 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: KF, PQ)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Petro Canada Lubricants Inc.
 385 Southdown Road
 Mississauga, ON
 CA L5J 2Y3
 Contact: Martin Wagenaar
 martin.wagenaar@HFSinclair.com
 T: (905)403-5682
 F: (905)822-6025