








PROBLEM SUMMARY

Area
3
 Machine Id
3-101-MG Primary
 Component
Crusher
 Fluid
MOBIL MOBILGEAR 600 XP 320 (2900 LTR)

Sample Rating Trend



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE	
Silicon	ppm	ASTM D5185(m)	>100	▲ 137	109	102
Particles >4µm		ASTM D7647	>20000	▲ 154328	▲ 227312	▲ 320843
Particles >6µm		ASTM D7647	>5000	▲ 144280	▲ 209156	▲ 288381
Particles >14µm		ASTM D7647	>640	▲ 83520	▲ 108104	▲ 122922
Particles >21µm		ASTM D7647	>160	▲ 39131	▲ 40058	▲ 31674
Particles >38µm		ASTM D7647	>40	▲ 257	▲ 126	50
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ 24/24/24	▲ 25/25/24	▲ 26/25/24

Customer Id: STMBOW
 Sample No.: WC0873668
 Lab Number: 02647222
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com


To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using IND 3 test kits,
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS


ISO




25 Jun 2024 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). There is a high amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report




ISO




17 Jun 2024 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report




ISO



10 Jun 2024 Diag: Wes Davis

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

3

Machine Id

3-101-MG Primary

Component

Crusher

Fluid

MOBIL MOBILGEAR 600 XP 320 (2900 LTR)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Component wear rates appear to be normal (unconfirmed).

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. Calcium and/or magnesium levels higher than normal indicating possible contamination with cement dust, advise investigate. Calcium and/or magnesium levels higher than normal indicating possible lime contamination, advise investigate. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0873668	WC0925308	WC0925311
Sample Date	Client Info		08 Jul 2024	25 Jun 2024	17 Jun 2024
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	SEVERE

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>200	65	57	53
Chromium	ppm	ASTM D5185(m)	>15	<1	<1	<1
Nickel	ppm	ASTM D5185(m)	>15	1	<1	<1
Titanium	ppm	ASTM D5185(m)		2	2	2
Silver	ppm	ASTM D5185(m)		0	0	<1
Aluminum	ppm	ASTM D5185(m)	>50	47	39	35
Lead	ppm	ASTM D5185(m)	>100	10	8	7
Copper	ppm	ASTM D5185(m)	>200	44	40	38
Tin	ppm	ASTM D5185(m)	>15	5	4	4
Antimony	ppm	ASTM D5185(m)	>5	0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	57	25	26	24
Barium	ppm	ASTM D5185(m)	0.0	<1	<1	<1
Molybdenum	ppm	ASTM D5185(m)	2.0	0	0	0
Manganese	ppm	ASTM D5185(m)	0.0	<1	<1	<1
Magnesium	ppm	ASTM D5185(m)	0.0	22	19	17
Calcium	ppm	ASTM D5185(m)	42	480	401	378
Phosphorus	ppm	ASTM D5185(m)	399	318	308	305
Zinc	ppm	ASTM D5185(m)	13	6	6	6
Sulfur	ppm	ASTM D5185(m)	13649	14423	14162	14221
Lithium	ppm	ASTM D5185(m)		<1	<1	<1


CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>100	137	109	102
Sodium	ppm	ASTM D5185(m)		4	4	4
Potassium	ppm	ASTM D5185(m)	>20	21	17	16


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	154328	227312	320843
Particles >6µm	ASTM D7647	>5000	144280	209156	288381
Particles >14µm	ASTM D7647	>640	83520	108104	122922
Particles >21µm	ASTM D7647	>160	39131	40058	31674
Particles >38µm	ASTM D7647	>40	257	126	50
Particles >71µm	ASTM D7647	>10	13	1	1
Oil Cleanliness	ISO 4406 (c)	>21/19/16	24/24/24	25/25/24	26/25/24


▲ Particle Trend




▲ Silicon (ppm)




● Additives



● Aluminum (ppm)



● Aluminum (ppm)



FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.68	0.71	0.66	0.69


VISUAL

	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	VLITE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	HAZY
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES


	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	275	311	310	309

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0873668 **Received** : 10 Jul 2024
Lab Number : **02647222** **Tested** : 11 Jul 2024
Unique Number : 5812774 **Diagnosed** : 12 Jul 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

ST. MARYS CEMENT CO.
 400 BOWMANVILLE AVENUE
 BOWMANVILLE, ON
 CA L1C 7B5
 Contact: Carlos Barberi
 carlos.barberi@vcimentos.com
 T: (905)623-3341
 F: (905)623-4695