

COOLANT REPORT



Machine Id

WINDSOR REGIONAL #1

Component Coolant

Fluid CONVENTIONAL COOLANT (--- GAL)

DIAGNOSIS

Recommendation

The fluid is suitable for further service. Resample at the next service interval to monitor.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition


The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0849184	WC0569033	
Sample Date		Client Info		09 Jul 2024	08 Mar 2022	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR		UNK		
Specific Gravity		ASTM D1298*		1.065	1.067	
рН	Scale 0-14	ASTM D1287*	9.5	9.09	9.13	
Nitrites	ppm	Alcan Test Kit*	1500	1000	960	
Reserve Alkalinity	Scale 0-20	ASTM D1121*	8.5	2.8	3.0	
Percentage Glycol	%	ASTM D3321*	50	48.5	50.0	
Freezing Point	°C	ASTM D3321*	-40	-35	-38	
Carboxylate						
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		41	33	
Phosphorus	ppm	ASTM D5185(m)		292	268	
Boron	ppm	ASTM D5185(m)		186	214	
Molybdenum	ppm	ASTM D5185(m)		49	49	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	0	2	
Aluminum	ppm	ASTM D5185(m)	>10	<1	2	
Copper	ppm	ASTM D5185(m)	>10	0	2	
Lead	ppm	ASTM D5185(m)	>10	4	4	
Tin	ppm	ASTM D5185(m)	>10	0	<1	
Silver	ppm	ASTM D5185(m)	>10	0	<1	
Zinc	ppm	ASTM D5185(m)		<1	<1	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		1325	1090	
Potassium	ppm	ASTM D5185(m)		1430	1210	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	<1	2	
Magnesium	ppm	ASTM D5185(m)	>40	0	1	
Hardness	mg/L CaCO3	In-house*	<75	0	8	



COOLANT REPORT





Received

Diagnosed

Tested

: 10 Jul 2024

: 10 Jul 2024

: 11 Jul 2024 - Kevin Marson

Laboratory CALA Sample No. : WC0849184 Lab Number : 02647245 ISO 17025:2017 Accredited Laboratory Unique Number : 5812797 Test Package : COOL (Additional Tests: GlycolType) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

CF Industrial Products Inc. 1928 Road 3 East Kingsville, ON CA N9Y 2E5 Contact: Dan Hammond danh@cfgroups.com T: (519)564-2241 F: (519)322-2916

Report Id: CFILEA [WCAMIS] 02647245 (Generated: 07/11/2024 12:17:59) Rev: 1

Submitted By: Dan Hammond Page 2 of 2