


FUEL REPORT

KONSTRUT SW50273

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR





Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.


Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

R) (GAL)			Mar2024	Jul2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0938144	WC0906287	
Sample Date		Client Info		09 Jul 2024	27 Mar 2024	
Machine Age	hrs	Client Info		0	0	
Sample Status				NORMAL	NORMAL	
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.849	0.851	
Fuel Color	text	Visual Screen*	Yllow	Yllow	Red	
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.6	2.8	
Pensky-Martens Flash Point	°C	ASTM D7215*	52	63.4	58.5	
SULFUR CONTE	٧T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	13	9	
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	175	171	
5% Distillation Point	°C	ASTM D2887*		204	201	
10% Distill Point	°C	ASTM D2887*	201	214	212	
15% Distillation Point	°C	ASTM D2887*		222	220	
20% Distill Point	°C	ASTM D2887*	216	230	228	
30% Distill Point	°C	ASTM D2887*	230	243	242	
40% Distill Point	°C	ASTM D2887*	243	254	255	
50% Distill Point	°C	ASTM D2887*	255	265	267	
60% Distill Point	°C	ASTM D2887*	267	277	280	
70% Distill Point	°C	ASTM D2887*	280	289	292	
80% Distill Point	°C	ASTM D2887*	295	302	305	
85% Distillation Point	°C	ASTM D2887*		312	315	
90% Distill Point	°C	ASTM D2887*	310	322	325	
95% Distillation Point	°C	ASTM D2887*		338	341	
Final Boiling Point	°C	ASTM D2887*	341	358	367	
IGNITION QUALIT	Υ	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	35	34	
Cetane Index		ASTM D4737*	<40.0	46	46	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0	0	
Sodium	ppm	ASTM D5185(m)	<0.1	0	<1	
Potassium	ppm	ASTM D5185(m)	<0.1	0	0	
Water	%	ASTM D6304*	< 0.05	0.005	0.003	
ppm Water	ppm	ASTM D6304*	<500	52	28	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>2500	512	788	
Particles >6µm		ASTM D7647	>640	181	200	
Particles >14μm		ASTM D7647	>80	26	16	
Particles >21µm		ASTM D7647	>20	8	3	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>18/16/13	16/15/12	17/15/11	



FUEL REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

Lab Number : 02647251

: WC0938144

Unique Number : 5812803

Received : 10 Jul 2024 **Tested** : 15 Jul 2024

Diagnosed : 15 Jul 2024 - Kevin Marson

Test Package : FUEL (Additional Tests: CC Flash, PrtCount) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

1919 WILSON AVE TORONTO, ON **CA M9M 1A9** Contact: Grant Brouwer grant@kooybros.com

T: (416)242-3513 F: (416)242-6710

Report Id: KOOTOR [WCAMIS] 02647251 (Generated: 07/15/2024 09:06:07) Rev: 1

Contact/Location: Grant Brouwer - KOOTOR