




# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id

## DAEWOO TOWERSIDE PG1

Component

Propane Engine

Fluid

PETRO CANADA SENTRON LD 5000 (--- GAL)

### DIAGNOSIS

#### ▲ Recommendation

Please note that all wear metal and contaminant levels are being considered accumulative. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 2 test kits, this testkit includes BN to determine the suitability of the oil for continued use.

#### ▲ Wear

Lead ppm levels are marginal. A sharp increase in the lead level is noted. Bearing wear is indicated.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The oil is no longer serviceable as a result of the abnormal and/or severe wear.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0915629</b>	PC0078885	PC0073810
Sample Date	Client Info		<b>27 May 2024</b>	31 Jan 2024	27 Oct 2023
Machine Age	hrs	Client Info	<b>12762</b>	12045	11485
Oil Age	hrs	Client Info	<b>717</b>	570	640
Oil Changed	Client Info		<b>Changed</b>	Changed	Changed
Sample Status			<b>MARGINAL</b>	NORMAL	ABNORMAL

### CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

### WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>100	<b>20</b>	23	29
Chromium	ppm	ASTM D5185(m)	>25	<b>4</b>	5	5
Nickel	ppm	ASTM D5185(m)	>5	<b>2</b>	<1	1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>5</b>	5	6
Lead	ppm	ASTM D5185(m)	>25	<b>▲ 20</b>	2	3
Copper	ppm	ASTM D5185(m)	>35	<b>50</b>	3	6
Tin	ppm	ASTM D5185(m)	>8	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	2	<b>3</b>	1	<1
Barium	ppm	ASTM D5185(m)	3	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	0	<b>2</b>	<1	<1
Manganese	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185(m)	4	<b>9</b>	11	10
Calcium	ppm	ASTM D5185(m)	1727	<b>2015</b>	2044	2013
Phosphorus	ppm	ASTM D5185(m)	272	<b>330</b>	325	346
Zinc	ppm	ASTM D5185(m)	333	<b>403</b>	387	414
Sulfur	ppm	ASTM D5185(m)	3415	<b>2964</b>	2874	3011
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

### CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>50	<b>3</b>	2	3
Sodium	ppm	ASTM D5185(m)		<b>44</b>	4	1
Potassium	ppm	ASTM D5185(m)	>20	<b>4</b>	<1	<1
Glycol	%	ASTM D7922*		<b>0.0</b>	---	---

### INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>7.8</b>	7.7	8.5
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>17.4</b>	17.5	18.6


### FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>12.1</b>	11.8	12.9




# OIL ANALYSIS REPORT


### ▲ Non-ferrous Metals




### Glycol Contamination



### FT-IR (Direct Trend)



### Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG ▲ .2%
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	13.4	13.7	13.6 13.5

### GRAPHS


#### Iron (ppm)




#### ▲ Lead (ppm)




#### Aluminum (ppm)




#### Chromium (ppm)




#### Copper (ppm)




#### Silicon (ppm)



#### Viscosity @ 100°C



#### Additives



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0915629 **Received** : 11 Jul 2024  
**Lab Number** : **02647335** **Tested** : 12 Jul 2024  
**Unique Number** : 5812887 **Diagnosed** : 15 Jul 2024 - Kevin Marson  
**Test Package** : MOB 1 ( Additional Tests: GLYCOL )

**Martin Energy Group Canada**  
 5531 Schummer Line  
 Linwood, ON  
 CA N0B 2A0  
 Contact: J Wagler  
 jwagler@martinenergygroup.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.