




OIL ANALYSIS REPORT

Sample Rating Trend



VISUAL METAL



Machine Id
CO-GEN #2
 Component
Turbine
 Fluid
MOBIL JET OIL II (120 GAL)

DIAGNOSIS

Recommendation

We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

Light concentration of visible metal present. All other component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0917353	WC0917351	WC0917348
Sample Date	Client Info		04 Jul 2024	06 Jun 2024	09 May 2024
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ATTENTION	MARGINAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>5	3	2	3
Chromium	ppm	ASTM D5185(m)	>2	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	<1	0	0
Titanium	ppm	ASTM D5185(m)	>2	0	0	0
Silver	ppm	ASTM D5185(m)	>2	<1	0	0
Aluminum	ppm	ASTM D5185(m)	>2	<1	0	0
Lead	ppm	ASTM D5185(m)	>4	0	0	0
Copper	ppm	ASTM D5185(m)	>2	2	2	2
Tin	ppm	ASTM D5185(m)	>3	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0.5	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0.0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0.0	0	0	0
Manganese	ppm	ASTM D5185(m)	0.0	0	0	0
Magnesium	ppm	ASTM D5185(m)	0.0	0	0	<1
Calcium	ppm	ASTM D5185(m)	0.0	<1	0	0
Phosphorus	ppm	ASTM D5185(m)	3039	2235	2230	2269
Zinc	ppm	ASTM D5185(m)	0.3	<1	<1	1
Sulfur	ppm	ASTM D5185(m)	38	3	4	3
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>5	0	0	0
Sodium	ppm	ASTM D5185(m)		<1	<1	0
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Water	%	ASTM D6304*	>.1	0.099	0.086	0.047
ppm Water	ppm	ASTM D6304*	>1000	992	861	472

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	2475	947	879
Particles >6µm	ASTM D7647	>640	763	277	226
Particles >14µm	ASTM D7647	>80	64	32	16
Particles >21µm	ASTM D7647	>20	20	16	6
Particles >38µm	ASTM D7647	>4	2	2	1
Particles >71µm	ASTM D7647	>3	0	0	1
Oil Cleanliness	ISO 4406 (c)	>18/16/13	18/17/13	17/15/12	17/15/11

Particle Filter (Magn: 200 x)





OIL ANALYSIS REPORT




FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.05	0.18	0.18	0.11

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	▲ VLITE	▲ VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	25.4	26.7	26.5	26.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0917353 **Received** : 11 Jul 2024
Lab Number : **02647339** **Tested** : 16 Jul 2024
Unique Number : 5812891 **Diagnosed** : 16 Jul 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FILTERPATCH, PrtFilter)

SANOI PASTEUR LIMITED
 1755 STEELES AVENUE WEST
 TORONTO, ON
 CA M2R 3T4
 Contact: Steven Joki
 steven.joki@sanofi.com
 T: (416)667-2701
 F: (416)667-2720

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.