




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

Power Generation

Machine Id

V837270 STANDBY POWER GENERATION 4160B PACKAGE

Component

Diesel Engine

Fluid

MOBIL DELVAC MX EXTRA 0W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PP14001678	PP13932690	PP13869146
Sample Date	Client Info		08 Jun 2024	25 Nov 2023	30 May 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	<1.0	<1.0
Water	WC Method	>0.2	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>100	4	3
Chromium	ppm	ASTM D5185(m)	>20	0	0
Nickel	ppm	ASTM D5185(m)	>4	<1	<1
Titanium	ppm	ASTM D5185(m)		0	0
Silver	ppm	ASTM D5185(m)	>3	0	<1
Aluminum	ppm	ASTM D5185(m)	>20	2	2
Lead	ppm	ASTM D5185(m)	>40	0	<1
Copper	ppm	ASTM D5185(m)	>330	4	3
Tin	ppm	ASTM D5185(m)	>15	0	0
Antimony	ppm	ASTM D5185(m)		0	0
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		2	2
Barium	ppm	ASTM D5185(m)		0	<1
Molybdenum	ppm	ASTM D5185(m)		0	0
Manganese	ppm	ASTM D5185(m)		0	0
Magnesium	ppm	ASTM D5185(m)		8	8
Calcium	ppm	ASTM D5185(m)		2110	2155
Phosphorus	ppm	ASTM D5185(m)		893	907
Zinc	ppm	ASTM D5185(m)		1058	1091
Sulfur	ppm	ASTM D5185(m)		2994	3018
Lithium	ppm	ASTM D5185(m)		<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	5	5
Sodium	ppm	ASTM D5185(m)		2	2
Potassium	ppm	ASTM D5185(m)	>20	<1	0


INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	>3	0	0
Nitration	Abs/cm	ASTM D7624*	>20	7.4	7.1
Sulfation	Abs./1mm	ASTM D7415*	>30	16.5	16.7




OIL ANALYSIS REPORT


FT-IR (Direct Trend)



Base Number



Viscosity @ 100°C



FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	14.3	14.5
Base Number (BN)	mg KOH/g	ASTM D2896*	8.95	6.81	8.25

VISUAL


	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*	NEG	NEG	NEG

FLUID PROPERTIES


	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	13.6	13.7	14.0

GRAPHS


Ferrous Alloys




Non-ferrous Metals



Viscosity @ 100°C



Base Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP14001678
Lab Number : 02647730
Unique Number : 5813282
Test Package : MAR 2

Received : 15 Jul 2024
Tested : 15 Jul 2024
Diagnosed : 15 Jul 2024 - Wes Davis

ExxonMobil Canada East Ltd.
 Hebron-Materials and Repair Coordin, Suite 1000, 100 New Gow
 St. John`s, NL
 CA A1C 6K3
 Contact: Liam Maher
 liam.m.maher@exxonmobil.com
 T: (709)273-3729
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.