

## **OIL ANALYSIS REPORT**

Sample Number

# **PUMPHOUSE/CASTER SPRAY WATER PUMPS** C - Caster Spray Water Turbine IB

Lube System

PETRO CANADA HYDREX AW 100 (1 GAL)

### DIAGNOSIS

## Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We recommend that you drain the oil from the component if this has not already been done. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

## A Wear


Copper ppm levels are abnormal. Lead and tin ppm levels are noted. Light concentration of visible metal present. Cylinder wear is indicated. Oil cooler core leaching or motor piston wear is indicated.

#### Contamination


Light concentration of visible dirt/debris present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.







Sample Date		Client Info		17 Jul 2024	10 Jan 2024	16 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*	>DFLT	0	1	0
Iron	ppm	ASTM D5185(m)	>20	2	3	2
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	<1	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	<1
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>20	<mark> </mark> 5	3	<1
Copper	ppm	ASTM D5185(m)	>20	<b>3</b> 2	13	4
Tin	ppm	ASTM D5185(m)	>20	<u> </u>	9	8
Antimony	ppm	ASTM D5185(m)		<1	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	0	0	<1
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	<1	<1	<1
Calcium	ppm	ASTM D5185(m)	50	45	48	51
Phosphorus	ppm	ASTM D5185(m)	330	322	319	322
Zinc	ppm	ASTM D5185(m)	430	388	405	397
Sulfur	ppm	ASTM D5185(m)	760	2416	2549	2381
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	3	3	3
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	0	<1	0



## **OIL ANALYSIS REPORT**

method

ASTM D7647

ASTM D7647 >10240000

ASTM D7647 >10240000

ASTM D7647 >2560000

limit/base

current

70850

13060

1109

270

history1

102626

17767

503

51

history2

60947

5540

315

82


**FLUID CLEANLINESS** 


Particles >4µm


Particles >6µm


Particles >14µm


Particles >21µm













647 >640000 647 >160000 647 >160000 647 >160000 647 >160000 64 Iimit/base 74* 0.60 64 Iimit/base NONE NONE NONE NONE NONE NONE NONE NON	0.34	1 0 24/21/16 history1 0.38 NONE NONE NONE NONE NONE NONE NONE NON	1 0 23/20/15 history2 0.70 history2 NONE NONE NONE VLITE VLITE VLITE NORE NORML NORML NORML NEG
i (c) >/30/30 d limit/base 74* 0.60 d limit/base NONE	23/21/17 current 0.34 VLITE NONE NONE NONE LIGHT NONE NORML NORML NORML NEG	24/21/16 history1 0.38 NONE NONE NONE NONE NONE NONE NONE NON	23/20/15 history2 0.70 NONE NONE NONE VLITE VLITE VLITE NONE NORML NORML NORML NEG
d limit/base 74* 0.60 d limit/base NONE NONE NONE NONE NONE NONE NONE NORML NORML >1	Current 0.34 Current VLITE NONE NONE NONE LIGHT NORML NORML NORML NEG	history1 0.38 history1 NONE NONE NONE NONE NONE NONE NONE NON	history2 0.70 NONE NONE NONE VLITE VLITE VLITE NORE NORML NORML NEG
174* 0.60 d limit/base NONE NONE NONE NONE NONE NORML NORML >1	0.34 Current VLITE NONE NONE NONE LIGHT NORML NORML NORML NEG	0.38 history1 NONE NONE NONE NONE NONE NONE WGOIL NORML .2%	0.70 history2 NONE NONE NONE VLITE VLITE NONE NORML NORML NEG
d limit/base NONE NONE NONE NONE NONE NORML NORML >1	Current Curren	history1 NONE NONE NONE NONE NONE NONE WGOIL NORML .2%	history2 NONE NONE NONE VLITE VLITE NONE NORML NORML NEG
NONE NONE NONE NONE NORML NORML >1	<ul> <li>VLITE</li> <li>NONE</li> <li>NONE</li> <li>LIGHT</li> <li>NORML</li> <li>NORML</li> <li>NEG</li> </ul>	NONE NONE NONE NONE NONE WGOIL NORML .2%	NONE NONE VLITE VLITE NONE NORML NORML NEG
NONE NONE NONE NONE NORML NORML >1	NONE NONE LIGHT NONE NORML NORML NEG	NONE NONE NONE NONE WGOIL NORML .2%	NONE NONE VLITE VLITE NONE NORML NORML NEG
NONE NONE NONE NORML NORML >1	NONE NONE LIGHT NORML NORML NORML NEG	NONE NONE NONE WGOIL NORML .2%	NONE VLITE VLITE NONE NORML NORML NEG
NONE NONE NORML NORML >1	NONE LIGHT NONE NORML NORML NEG	NONE NONE WGOIL NORML .2%	VLITE VLITE NONE NORML NORML NEG
NONE NORML NORML >1	LIGHT NONE NORML NORML NEG	NONE NONE WGOIL NORML .2%	VLITE NONE NORML NORML NEG
NONE NORML NORML >1	NONE NORML NORML NEG	NONE WGOIL NORML .2%	NONE NORML NORML NEG
NORML NORML >1	NORML NORML NEG	WGOIL NORML .2%	NORML NORML NEG
NORML >1	NORML NEG	NORML .2%	NORML NEG
>1	NEG	.2%	NEG
	NFG	A 10/	
		▲ 1 70	NEG
d limit/base	e current	history1	history2
9(m) 101	94.2	94.5	95.2
d limit/base	e current	history1	history2
			ACOBSUTET OF
	and a state of the	no image	no image
	· · /	()	d       limit/base       current       history1         Imit/base       Current       Imit/base       Imit/base         Imit/base       Imit/base       Imit/base       Imit/base         Imit

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 STELCO - BOSC - Basic Oxygen Slab Caster CALA Sample No. : WC0968458 Received : 17 Jul 2024 2330 Regional Road #3, Door: BOSC8 Lab Number : 02648435 Tested : 18 Jul 2024 NANTICOKE, ON ISO 17025:2017 Accredited Laboratory Unique Number : 5813987 Diagnosed : 19 Jul 2024 - Kevin Marson CA N0A 1L0 Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FILTERPATCH, PQ, PrtFilter Contact: Tom Walden To discuss this sample report, contact Customer Service at 1-800-268-2131. Thomas.Walden@stelco.com Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (519)587-4541 Validity of results and interpretation are based on the sample and information as supplied. F: (519)587-7702

Report Id: LEWBOSC [WCAMIS] 02648435 (Generated: 07/19/2024 10:26:08) Rev: 1

Submitted By: Bob Melanson Page 2 of 2