




PROBLEM SUMMARY


Area
RHOB/TREATED WATER PUMPS
 Machine Id
E - Treated Water Pump 1 Electric
 Component
Lube System
 Fluid
ESSO SPARTAN EP 220 (--- GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	NORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ 115946	---	▲ 38924
Particles >6µm	ASTM D7647	>1300	▲ 28478	---	▲ 5201
Particles >14µm	ASTM D7647	>160	▲ 1493	---	● 316
Particles >21µm	ASTM D7647	>40	▲ 288	---	● 67
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 24/22/18	---	▲ 22/20/15

Customer Id: LEWBOSC
 Sample No.: WC0968444
 Lab Number: 02648513
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

NORMAL



16 Sep 2018 Diag: Kevin Marson

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



WEAR



20 May 2015 Diag: Kevin Marson

Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit. Aluminum and copper ppm levels are noted. All other component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. Particles >21µm are notably high. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. Viscosity of sample indicates oil is within SAE 90 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



ISO



19 Mar 2015 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. We recommend that you drain the oil from the component if this has not already been done. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. Particles >6µm are severely high. Particles >4µm are severely high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
RHOB/TREATED WATER PUMPS
 Machine Id
E - Treated Water Pump 1 Electric
 Component
Lube System
 Fluid
ESSO SPARTAN EP 220 (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0968444	WC22131695	WC22116123
Sample Date	Client Info		17 Jul 2024	16 Sep 2018	20 May 2015
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>5	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>DFLT	0	26	9
Iron	ppm	ASTM D5185(m) >20	31	191	17
Chromium	ppm	ASTM D5185(m) >20	0	<1	<1
Nickel	ppm	ASTM D5185(m) >20	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	<1
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >20	<1	<1	9
Lead	ppm	ASTM D5185(m) >20	0	1	3
Copper	ppm	ASTM D5185(m) >20	<1	<1	16
Tin	ppm	ASTM D5185(m) >20	0	0	<1
Antimony	ppm	ASTM D5185(m)	0	0	<1
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	<1

ADDITIVES






	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) .5	1	5	37
Barium	ppm	ASTM D5185(m)	<1	0	<1
Molybdenum	ppm	ASTM D5185(m) 0	0	<1	<1
Manganese	ppm	ASTM D5185(m)	<1	2	2
Magnesium	ppm	ASTM D5185(m) 0	1	3	2
Calcium	ppm	ASTM D5185(m) 1.7	8	18	10
Phosphorus	ppm	ASTM D5185(m) 250	311	227	924
Zinc	ppm	ASTM D5185(m) .3	28	42	154
Sulfur	ppm	ASTM D5185(m)	10752	9210	14149
Lithium	ppm	ASTM D5185(m)	1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	7	2	9
Sodium	ppm	ASTM D5185(m)	<1	4	<1
Potassium	ppm	ASTM D5185(m) >20	<1	1	2



OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0968444
Lab Number : 02648513
Unique Number : 5814065
Test Package : IND 2 (Additional Tests: Bottom, PQ, TAN Man)

STELCO - BOSC - Basic Oxygen Slab Caster
 2330 Regional Road #3, Door: BOSC8
 NANTICOKE, ON
 CA N0A 1L0
 Contact: Tom Walden
 Thomas.Walden@stelco.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T: (519)587-4541
 F: (519)587-7702


FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 115946	---	▲ 38924
Particles >6µm	ASTM D7647	>1300	▲ 28478	---	▲ 5201
Particles >14µm	ASTM D7647	>160	▲ 1493	---	● 316
Particles >21µm	ASTM D7647	>40	▲ 288	---	● 67
Particles >38µm	ASTM D7647	>10	5	---	3
Particles >71µm	ASTM D7647	>3	1	---	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 24/22/18	---	▲ 22/20/15

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974*	0.75	0.69	0.43	0.96

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	VLITE	NONE	NONE
Yellow Metal	scalar Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar Visual*	NONE	NONE	NONE	NONE
Silt	scalar Visual*	NONE	NONE	LIGHT	NONE
Debris	scalar Visual*	NONE	VLITE	NONE	VLITE
Sand/Dirt	scalar Visual*	NONE	NONE	NONE	NONE
Appearance	scalar Visual*	NORML	NORML	NORML	NORML
Odor	scalar Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual*	>5	NEG	NEG	5%
Free Water	scalar Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	220	201	224	▲ 139

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Color					
Bottom					