




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KOHLER 60 LEONARD AVE GEN #1

Component

Diesel Engine

Fluid

KLONDIKE HEAVY DUTY 15W40 (260 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. this testkit includes BN to determine the suitability of the oil for continued use.

Wear

Metal levels are typical for a new component breaking in. Component wear rates appear to be normal (unconfirmed).

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The condition of the oil is acceptable for the time in service (unconfirmed).

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | WC0965959 | WC0657597 | WC960210 |
| Sample Date | Client Info | | | 13 Jul 2024 | 08 Jun 2022 | 03 Jan 2018 |
| Machine Age | hrs | Client Info | | 125 | 0 | 98 |
| Oil Age | hrs | Client Info | | 0 | 0 | 98 |
| Oil Changed | Client Info | | | Changed | N/A | N/A |
| Sample Status | | | | NORMAL | NORMAL | NORMAL |

| CONTAMINATION | | method | limit/base | current | history1 | history2 |
|---------------|-----------|--------|------------|----------------|----------|----------|
| Fuel | WC Method | >5 | | <1.0 | <1.0 | <1.0 |
| Water | WC Method | >0.2 | | NEG | NEG | NEG |
| Glycol | WC Method | | | NEG | NEG | NEG |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|---------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185(m) | >100 | 1 | 2 | 4 |
| Chromium | ppm | ASTM D5185(m) | >20 | 0 | 0 | <1 |
| Nickel | ppm | ASTM D5185(m) | >4 | 0 | <1 | <1 |
| Titanium | ppm | ASTM D5185(m) | | <1 | 2 | 3 |
| Silver | ppm | ASTM D5185(m) | >3 | 0 | <1 | 0 |
| Aluminum | ppm | ASTM D5185(m) | >20 | <1 | <1 | 2 |
| Lead | ppm | ASTM D5185(m) | >40 | 0 | <1 | <1 |
| Copper | ppm | ASTM D5185(m) | >330 | 1 | <1 | 9 |
| Tin | ppm | ASTM D5185(m) | >15 | 0 | <1 | <1 |
| Antimony | ppm | ASTM D5185(m) | | 0 | 0 | 2 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |



| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|---------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185(m) | 70 | 304 | 92 | 30 |
| Barium | ppm | ASTM D5185(m) | | 0 | 0 | 4 |
| Molybdenum | ppm | ASTM D5185(m) | | 65 | 1 | 40 |
| Manganese | ppm | ASTM D5185(m) | | 0 | <1 | <1 |
| Magnesium | ppm | ASTM D5185(m) | 50 | 433 | 707 | 681 |
| Calcium | ppm | ASTM D5185(m) | 2000 | 1432 | 1294 | 1548 |
| Phosphorus | ppm | ASTM D5185(m) | 1000 | 1030 | 1057 | 1027 |
| Zinc | ppm | ASTM D5185(m) | 1100 | 1162 | 1136 | 1247 |
| Sulfur | ppm | ASTM D5185(m) | 3400 | 2862 | 3191 | 3046 |
| Lithium | ppm | ASTM D5185(m) | | <1 | 0 | <1 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|---------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185(m) | >25 | 4 | 5 | 3 |
| Sodium | ppm | ASTM D5185(m) | | 2 | 4 | 5 |
| Potassium | ppm | ASTM D5185(m) | >20 | <1 | 3 | 3 |

| INFRA-RED | | method | limit/base | current | history1 | history2 |
|-----------|----------|-------------|------------|-------------|----------|----------|
| Soot % | % | ASTM D7844* | >3 | 0 | 0 | 0 |
| Nitration | Abs/cm | ASTM D7624* | >20 | 5.0 | 4.8 | 6.1 |
| Sulfation | Abs./1mm | ASTM D7415* | >30 | 19.6 | 17.8 | 17.1 |



OIL ANALYSIS REPORT



FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 | |
|-----------|----------|-------------|---------|-------------|----------|------|
| Oxidation | Abs./1mm | ASTM D7414* | >25 | 14.1 | 8.9 | 12.7 |









VISUAL

| | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|------------|----------|-----|
| Emulsified Water | scalar | Visual* | >0.2 | NEG | NEG | NEG |
| Free Water | scalar | Visual* | | NEG | NEG | NEG |

FLUID PROPERTIES

| | method | limit/base | current | history1 | history2 | |
|--------------|--------|---------------|---------|-------------|----------|------|
| Visc @ 100°C | cSt | ASTM D7279(m) | 14.8 | 13.8 | 14.1 | 13.7 |

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **RONNIE'S GENERATOR SERVICE LTD.**
Sample No. : WC0965959 **Received** : 18 Jul 2024 **6459 NETHERHART ROAD**
Lab Number : **02648647** **Tested** : 18 Jul 2024 **MISSISSAUGA, ON**
Unique Number : 5814199 **Diagnosed** : 18 Jul 2024 - Wes Davis **CA L5T 1C3**
Test Package : MOB 1 **Contact:** Paul Praturlon

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
 F: (905)670-8819