




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**JAX-COMP01, WW-1**  
 Component  
**Compressor**  
 Fluid  
**MOBIL DTE OIL LIGHT (20 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the component.

### Fluid Condition

The condition of oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>RP75331</b>	RP095503	RP77278
Sample Date	Client Info		<b>14 Mar 2012</b>	14 Jun 2011	15 Apr 2009
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Chromium	ppm	ASTM D5185m	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m	<b>&lt;1</b>	<1	1
Copper	ppm	ASTM D5185m	<b>0</b>	<1	<1
Tin	ppm	ASTM D5185m	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m	<b>0</b>	0	9
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	<1	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>75</b>	84	83
Calcium	ppm	ASTM D5185m	<b>0</b>	0	2
Phosphorus	ppm	ASTM D5185m	<b>0</b>	10	<1
Zinc	ppm	ASTM D5185m	<b>0</b>	0	2




## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185m	<b>4</b>	0	8
Water	%	ASTM D6304	<b>0.035</b>	0.033	0.027
ppm Water	ppm	ASTM D6304	<b>350</b>	330	270

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.358</b>	0.616	0.650

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32.84	33.46	32.09

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP75331 **Received** : 26 Mar 2012  
**Lab Number** : 03040324 **Diagnosed** : 27 Mar 2012  
**Unique Number** : 5862372 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**SYMRISE**  
 601 CRESTWOOD ST  
 JACKSONVILLE, FL  
 US 32208  
 Contact: ADAM BOVITCH  
 ADAM.BOVITCH@SYMRISE.COM  
 T: (904)924-2765  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)