




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
CATERPILLAR 81Z12792
 Component
Diesel Engine
 Fluid
ROYAL PURPLE MOTOR OIL 15W40 (19 GAL)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the component.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		RP56631	RP104859	RP104855
Sample Date	Client Info		16 Sep 2013	19 Oct 2012	03 Oct 2011
Machine Age	hrs	Client Info	654	628	595
Oil Age	hrs	Client Info	321	183	150
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method		<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	29	27	27
Chromium	ppm	ASTM D5185m	<1	<1	<1
Nickel	ppm	ASTM D5185m	<1	<1	<1
Titanium	ppm	ASTM D5185m	0	<1	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m	2	3	2
Lead	ppm	ASTM D5185m	4	2	2
Copper	ppm	ASTM D5185m	258	265	195
Tin	ppm	ASTM D5185m	3	0	0
Antimony	ppm	ASTM D5185m	0	0	4
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	21	25	23
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	100	89	107
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	153	151	183
Calcium	ppm	ASTM D5185m	3116	3041	3383
Phosphorus	ppm	ASTM D5185m	1110	1081	1111
Zinc	ppm	ASTM D5185m	1236	1281	1263

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	4	5	6
Sodium	ppm	ASTM D5185m	6	6	5
Potassium	ppm	ASTM D5185m	3	2	0



INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	11.	9.	10.
Sulfation	Abs/.1mm	*ASTM D7415	29.	26.	28.

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	21.	18.	20.
Base Number (BN)	mg KOH/g	ASTM D2896	9.54	7.85	8.01









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.94	13.8	13.4
Fluid Type		*In-house	*SAE_ENG_DE	UNKNOWN	---

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP56631 **Received** : 25 Sep 2013
Lab Number : 03364294 **Diagnosed** : 27 Sep 2013
Unique Number : 6392047 **Diagnostician** : Wes Davis
Test Package : MOB 2 (Additional Tests: FluidDetermination)

GRAYLING GENERATING STATION
 4400 WEST FOUR MILE ROAD
 GRAYLING, MI
 US 49738
 Contact: JASON SHEA
 jason.j.shea@cmsenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (989)348-4679