

OIL ANALYSIS REPORT

Area [7193018] KAESER C-6F (S/N 752706)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Sample Rating Trend **NORMAL**

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system is acceptable. There is no indication of any contamination in the component.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	AATION	method	limit/base	Jun2015	history 1	history 2
	MATION		IIIIIVbase	current	history 1	flistory 2
Sample Number		Client Info		WCI2280895		
Sample Date		Client Info		23 Jun 2015		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	1		
Lead	ppm	ASTM D5185m	>10	2		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>10	0		
Antimony	ppm	ASTM D5185m		0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		<1		
Barium	ppm	ASTM D5185m	90	<1		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	90	<1		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		56		
Zinc	ppm	ASTM D5185m		8		
Sulfur	ppm	ASTM D5185m		654		
CONTAMINANTS	;	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID CLEANLIN	IESS _	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		679		
Particles >6µm		ASTM D7647	>1300	370		
Particles >14µm		ASTM D7647	>80	63		
Particles >21µm		ASTM D7647	>20	21		
Particles >38µm		ASTM D7647	>4	3		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/13		
FLUID DEGRADA	ATION _	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.312		



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: 03783379 : 7071404

: WCI2280895

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 16 Jul 2015 Diagnosed

: 20 Jul 2015 : Jonathan Hester Diagnostician

Test Package : IND 2 (Additional Tests: PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2290 CALLAHAN RD LONGVIEW, TX US 75607 Contact: ROB WALLIN

rwallin@westlake.com T: (903)242-7576 F: (903)758-9521