

PROBLEM SUMMARY

Sample Rating Trend




GENERAL ELECTRIC YG-7004 (S/N 155043)

Turbine

ROYAL PURPLE SYNFILM GT 32 (1540 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Copper	ppm	ASTM D5185m	>5	<u>^</u> 24	<u></u> 15	<u>17</u>	

Customer Id: REFESM Sample No.: RP180553 Lab Number: 04299427 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

30 Jan 2017 Diag: Don Baldridge

WEAR



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



21 Jul 2015 Diag: Jonathan Hester

WEAR



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



15 Mar 2013 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The condition of oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

GENERAL ELECTRIC YG-7004 (S/N 155043)

Component

Turbine

ROYAL PURPLE SYNFILM GT 32 (1540 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP180553	RP04160809	RP77978
Sample Date		Client Info		24 Aug 2017	30 Jan 2017	21 Jul 2015
Machine Age	hrs	Client Info		172848	168	154488
Oil Age	hrs	Client Info		102768	98	84408
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	<1	0	<1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m		0	0	0
Copper	ppm	ASTM D5185m	>5	<u>^</u> 24	<u>▲</u> 15	<u>▲</u> 17
Tin	ppm	ASTM D5185m	>5	<1	0	0
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		<1	0	0
Phosphorus	ppm	ASTM D5185m		5	4	3
Zinc	ppm	ASTM D5185m		1	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	ppm	ASTM D5185m	>20	<1	0	4
Water	%	ASTM D6304	>0.03	0.007	0.006	0.023
ppm Water	ppm	ASTM D6304	>300	70	60	230





OIL ANALYSIS REPORT












FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		11978	801	359.
Particles >6µm		ASTM D7647	>1300	1219	195	195.
Particles >14µm		ASTM D7647	>160	62	19	33.
Particles >21µm		ASTM D7647	>40	17	5	11.
Particles >38µm		ASTM D7647	>10	5	0	1.
Particles >71µm		ASTM D7647	>3	4	0	0.
Oil Cleanliness		ISO 4406 (c)	>/17/14	21/17/13	17/15/11	16/15/12
Particles 5-15µm	count	*NAS 1638	>1300	113017	17095	
Particles 15-25µm	count	*NAS 1638	>160	3626	1349	
Particles 25-50µm	count	*NAS 1638	>40	833	516	
Particles 50-100µm	count	*NAS 1638	>10	74	0	
Particles >100μm	count	*NAS 1638	>3	409	0	
NAS Code		*NAS 1638	>/17/14	11	7	
FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	ma 1/011/a	ACTM DODAE		0.047	0.000	0.050

-					,	,
Acid Number (AN)	mg KOH/g	ASTM D8045		0.317	0.322	0.350
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	VLITE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2

Visc @ 40°C cSt ASTM D445 32 30.51 30.49 31.28 SAMPLE IMAGES limit/base method current history1 history2

Color



no image

Bottom

no image



Certificate L2367

Laboratory Sample No. Lab Number

Unique Number

: RP180553 : 04299427 : 7922965

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 07 Sep 2017 Diagnosed : 11 Sep 2017

Diagnostician : Don Baldridge **Test Package**: IND 2 (Additional Tests: PrtCount, PrtCountNAS)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

REFINERIA ESMERALDAS KM 7 1/2 VIA ATACAMES ESMERALDAS,

EC

Contact: MILTON PALADINES miltonhpr@yahoo.es

T:

F: