


PROBLEM SUMMARY

Area [9381690] GARDNER DENVER C-8 (S/N S521766)


Compressor


GARDNER DENVER AEON 9000 SP (--- GAL)





COMPONENT CONDITION SUMMARY





RECOMMENDATION

We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL				
Water	%	ASTM D6304	>0.1	△ 0.329				
ppm Water	ppm	ASTM D6304	>1000	3290				
Particles >14µm		ASTM D7647	>320	4 359				
Particles >21µm		ASTM D7647	>80	<u> </u>				
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u> </u>				
Appearance	scalar	*Visual	NORML	LAYRD				
Free Water	scalar	*Visual		<u>^</u> 2.0				

Customer Id: WESLONWC Sample No.: WCI2317641 Lab Number: 04413728 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Water Drain-off	MISSED	Jun 27 2018	?	We advise that you follow the water drain-off procedure for this component.			
Resample	MISSED	Jun 27 2018	?	We recommend an early resample to monitor this condition.			

HISTORICAL DIAGNOSIS




OIL ANALYSIS REPORT

Area [9381690] GARDNER DENVER C-8 (S/N S521766)

Compressor

GARDNER DENVER AEON 9000 SP (--- GAL)





DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil. Free water present.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

KL)				Jan 2018		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		WCI2317641		
Sample Date		Client Info		24 Jan 2018		
Machine Age	hrs	Client Info		4462		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Antimony	ppm	ASTM D5185m		0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	2		
Barium	ppm	ASTM D5185m	0	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	0	0		
Calcium	ppm	ASTM D5185m	0	<1		
Phosphorus	ppm	ASTM D5185m	800	655		
Zinc	ppm	ASTM D5185m	0	<1		
Sulfur	ppm	ASTM D5185m	0	19		
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	4		
Water	%	ASTM D6304	>0.1	△ 0.329		
ppm Water	ppm	ASTM D6304	>1000	△ 3290		
FLUID CLEANLIN	ESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>10000	3871		
Particles >6µm		ASTM D7647	>2500	2109		
Particles >14μm		ASTM D7647	>320	4 359		
Particles >21µm		ASTM D7647	>80	<u> </u>		
Particles >38µm		ASTM D7647	>20	18		
Particles >71μm		ASTM D7647	>4	1		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	1 9/18/16		
FLUID DEGRADA	TION	method	limit/base	current	history 1	history 2
Acid Number (AN)	та КОЦ/а	VCTM DOUVE	170	0.257		



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: WCI2317641 : 04413728 : 8107432

Received : 22 Feb 2018 Diagnosed

: 23 Feb 2018 Diagnostician : Doug Bogart

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

2290 CALLAHAN RD LONGVIEW, TX US 75607

Contact: ROB WALLIN rwallin@westlake.com T: (903)242-7576

F: (903)758-9521

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)