

PROBLEM SUMMARY


Sample Rating Trend

WATER

GARDNER DENVER C-2 (S/N M60451)


Compressor

GARDNER DENVER AEON 9000 TH (--- GAL)





COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	ATTENTION		
Water	%	ASTM D6304	>0.1	<u> </u>	△ 0.388			
ppm Water	ppm	ASTM D6304	>1000	1560	▲ 3880			
Debris	scalar	*Visual	NONE	▲ HEAVY	▲ HEAVY	VLITE		

Customer Id: WESLONWC **Sample No.:** WCI2313672 **Lab Number:** 04555173 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Jul 15 2019	?	We recommend you service the filters on this component.
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

24 Jan 2018 Diag: Jonathan Hester

WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. High concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

24 Oct 2017 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

14 Jun 2016 Diag: Don Baldridge

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



GARDNER DENVER C-2 (S/N M60451)

Compressor

GARDNER DENVER AEON 9000 TH (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

High concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

L)		Jun2015	Oct2015 Mar2016	Jun2016 Oct2017 Jan2018	Aug2018	
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		WCI2313672	WCI2323421	WCI2328286
Sample Date		Client Info		30 Aug 2018	24 Jan 2018	24 Oct 2017
Machine Age	hrs	Client Info		37393	36654	35088
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	6	2	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	<1	<1
Lead	ppm	ASTM D5185m	>25	<1	<1	1
Copper	ppm	ASTM D5185m	>50	2	2	1
Tin	ppm	ASTM D5185m	>15	<1	0	<1
Antimony	ppm	ASTM D5185m		2	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		<1	4	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	1	<1
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		<1	0	0
Phosphorus	ppm	ASTM D5185m		688	631	722
Zinc	ppm	ASTM D5185m		3	<1	<1
Sulfur	ppm	ASTM D5185m		109	74	10
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	6	6	2
Sodium	ppm	ASTM D5185m		0	3	0
Potassium	ppm	ASTM D5185m	>20	1	4	0
Water	%	ASTM D6304	>0.1	△ 0.156	△ 0.388	
ppm Water	ppm	ASTM D6304	>1000	1560	▲ 3880	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>10000			<u> </u>
Particles >6µm		ASTM D7647	>2500			▲ 3126
Particles >14µm		ASTM D7647	>320			<u>494</u>
Particles >21µm		ASTM D7647	>80			<u>^</u> 215
Particles >38µm		ASTM D7647	>20			▲ 32
Particles >71µm		ASTM D7647	>4			<u>\$\infty\$ 5</u>
Oil Cleanliness		ISO 4406 (c)	>20/18/15			<u>△</u> 21/19/16
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2
	140111	4.0TH D.04 :-			0.500	

Acid Number (AN)


mg KOH/g ASTM D8045

0.538 Contact/Location: ROB WALLIN - WESLONWC

0.493



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Unique Number Test Package : IND 2 (Additional Tests: KF, PrtCount)

: WCI2313672 : 04555173 : 8339031

Received

: 20 Sep 2018 Diagnosed : 23 Sep 2018 Diagnostician : Doug Bogart

Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

WESTLAKE CHEMICAL

2290 CALLAHAN RD LONGVIEW, TX US 75607

Contact: ROB WALLIN rwallin@westlake.com

Contact/Location: ROB WALLIN - WESLONWC

T: (903)242-7576 F: (903)758-9521